


Project Manual

Harbor Terrace Elevator Modernization

Portland, Maine

Architect's Project No.
20034

Issued: December 08, 2020
For Bidding



Project Team

Portland Housing Authority

14 Baxter Blvd
Portland, ME 04101

CWS Architects

264 US Route One, Suite 100-2A
Scarborough, ME 04074
Tel: 207.774.4441

Bennett Engineering

P.O. Box 297
Freeport, ME 04032
Tel: 207.865.9475

DOCUMENT 00 01 10

TABLE OF CONTENTS

SPECIFICATIONS

Table of Contents

14 21 01	Geared Traction Elevator Modernization
14 21 01-2	Geared Traction Elevator Modernization - Appendix
26 00 00	General Electrical Requirements
26 05 19	Low-Voltage Electrical Power Conductors and Cables
26 05 26	Grounding and Bonding for Electrical Systems
26 05 33	Raceways and Boxes for Electrical Systems
26 19 00	Supporting Devices
26 27 26	Wiring Devices
28 31 11	Digital, Addressable Fire-Alarm System

DRAWINGS

CP COVER PAGE, DRAWING INDEX, AND GENERAL NOTES

ARCHITECTURAL DRAWINGS

A1.10 HARBOR TERRACE ELEVATOR REMOVALS AND NEW WORK PLANS

ELECTRICAL DRAWINGS

E1.00 HARBOR TERRACE ELECTRICAL PLANS

END OF TABLE OF CONTENTS

DOCUMENT 14 21 01

GEARED TRACTION ELEVATOR MODERNIZATION

Equipment Description – Harbor Terrace (PHA)

Rated load	Car #1 2500lbs Car #2 2000lbs
Rated speed	250 fpm (Verify in field)
Travel height	70 ft 0 in (Verify in Field)
Number of floors	8 floors

Cars #1, and #2 at Harbor Terrace are originally vendor products installed by Pine State Elevator. Original Hollister Whitney #43 Overhead Geared Machines in place, with newer Hollister Whitney governors, MCE VFMC AC Geared elevator controls (2003) and Hollister Whitney rope grippers

Building has fixtures installed in approximately 2003 and GAL door operating equipment. The Otis hatch side equipment and locks has been retained on Franklin Tower and Harbor Terrace has all GAL on the car and hatch side.

2. Elevator Technical Specification – Franklin Tower and Harbor Terrace

Elevator / Solution 1

Car	Cab
Number of floors served:	8
Type of Cab	Interior Only

A \$15,000 per elevator allowance is to be carried for the furnish and installation of a new elevator cab interior including 3 wall panel system, LED downlight ceiling, cab handrails on all 3 walls, and new front return skins and front return transom. New commercial grade rubber tile floor to be provided. Choices made from standard vendor interior packages and standard finishes.

Acceptable Vendors:

Snap Cab

Fab a Cab

Elevator Interiors Inc (Interflex)

Doors

Product name	Door Panel(s)
Car Panel Finishing Material	New car door panel(s) shall be provided. New door(s) shall be UL fire rated 1 ½ hour. Finish will be #4 stainless steel.
Door type	Single speed side opening
Door width [in]	42
Door Height (in)	84
Hatch Panel Finishing Material	New hatch door panel(s) shall be provided at main lobby only where applicable. New door(s) shall be UL fire rated 1 ½ hour. Finish will be #4 stainless steel.

Main Lobby entrances to re skinned in #4 stainless steel complete

Elevator door protection

Curtain of Light

Code year	2017
Hoistway NEMA Rating	Hoistway rating is NEMA 1.
Front/rear entrances	Front entrances only
Type of Curtain of light (COL)	This curtain of light is an electronic sensing device which operates across the car entrance. When activated, the curtain of light will prevent the doors from closing or cause them to stop and reopen if they are in the process of closing. The doors will remain open as long as the flow of traffic continues and will close shortly after the last person passes through the door opening. A 3-D type will be provided.

Door Operating Equipment

GAL Door Equipment (Or approved OEM or Vendor products substitute)

Elevator Group Size	(2) two cars
Number of floors served:	8
Hoistway NEMA Rating	Hoistway rating is NEMA 1.
Front/rear entrances	Front entrances only
Number of front openings:	8
Number of rear openings	0
Car Hanger and Track	A new car hanger and track will be provided.
Door type	Single speed side opening
Door width [in]	42/36
Hatch Door Closer	New hatch door closers will be provided at the specified number of openings.
Hatch Door Drive and interlock	New hatch door drives and interlocks will be provided at the specified number of openings.

Harbor Terrace: Existing hatch doors to remain apart from the main lobby. All car and Hatch side door equipment to be replaced with new. Car door hangers, tracks, clutch, Hatch door hangers, tracks, locks, closers. Hatch door header to be reused. **GAL MOVFR2** or approved equal.

Acceptable Substitutes:

“Awarded Contractor,” Otis, Schindler, ThyssenKrupp standard offering.

MAC

Elevator Monitoring System – Building Management

Number of floors served:	8
Machine Room NEMA Rating	Machine room rating is NEMA 1.
COP quantity	1
Monitoring Type	A system will be installed in each building enables you to monitor your elevator in one or several buildings from a single location. This shall be a a full-featured facilities management tool designed to ensure the best possible tenant service quality, reliability and efficiency of the elevators in the building. It shall be able utilized as a standalone supervisory tool to enhance the management of virtually any type of installations, new or existing. It should have the capability to be monitor multiple buildings remotely with building network interface is owner desires and allows network access.

Acceptable Vendors/Products

All OEM standard Monitoring systems

3rd Party controls Monitoring systems standard offerings

New AC Gearless

Elevator Group Size	Duplex
Capacity [LBS]	2500/2000
Speed [FPM]	250 (VIF)
Machine Room NEMA Rating	Machine room rating is NEMA 1.
New Roping Ratio	1:1
Machine Type	AC Gearless with Permanent Magnet motors and REGEN Capable design. Machine must use tradition steel cables.

Acceptable Suppliers;

- All standard OEM product lines using traditional steel cables for means of suspension
- Imperial Electric
- Torin Machine
- Hollister Whitney

Shaft equipment

Elevator Compensation	Comp. Ropes & chains
Travel (in)	Verify in Field
Capacity [LBS]	2500/2000
Speed [FPM]	250 (VIF)
New Roping Ratio	1:1
Compensation Type	New Whisperflex style compensation will be provided to insure proper counter balance in accordance with application criteria. (if needed – see notes below)
Compensation Quantity	1
Guidance system	Yes

Compensation only required at Harbor Terrace if required by product design engineers in geared to gearless conversion.

Elevator Guide Rollers	Guides – Car and Counterweight
Capacity [LBS]	2500/2000
Speed [FPM]	250
Car Guide Dust Covers	Yes
Car guide shoes adapters	Yes
Car Guideshoe Type	Elsco B (Roller) or Hollister Whitney as approved equal
Counterweight guide shoes adapters	Yes
CWT Guide Dust Covers	Yes
CWT Guideshoe Type	Elsco D (Roller)

Steel cables	Traction Ropes
Travel (in)	Verify in field
Capacity [LBS]	2500
New Roping Ratio	1:1
Pit depth (in) [match pre-existing conditions]	72 verify in field
Overhead height (in) [match pre-existing conditions]	240 verify in field
Shackles	New wedge shackles will be provided.



Existing elevator Hollister Whitney Governors to be cleaned, painted, adjusted, refurbished, and if properly functional per code, re used. New Governor cable to be provided.

Car and Hall Fixture Packages

Number of floors served:	8
Capacity [LBS]	2500/2000
Front/rear entrances	Front entrances only
Number of front openings:	8
Number of rear openings	0
Card Reader Provisions	N/A
Car Station	1 Car operating Panel to be provided per elevator. Flush mounted in front returns in current location. Include Emergency Contact System as required by code.
Qty of new hall stations:	8
Qty of new hall lanterns	NONE - Any existing Hall lanterns, PI's, switch plates, etc. shall be removed and replaced with Blank stainless steel plates
Qty of new hall position indicators	1 New Digital Hall Position Indicators will be provided at Main Lobby only
Qty of car direction lanterns	1 New Car Travelling Lantern will be installed in each elevator in the appropriate jamb per ADA visibility requirements from Hall stations
Qty of hoistway access switches	2 New switch assembly and fixture to be flush mounted at the top and bottom landings of each elevator for hoistway access per code
Car Sanitization Air Filtration System	Provide Mechanical Air Filtration System (1) per car, equipped with disinfectant-coated filter, rated for 12 air exchanges per hour.
Car Sanitization UV Light	Provide UV Sanitization system (1) per car.
Car and Hall Station Add Alternate	Provide alternate pricing for touchless Car Station (1) per car Operating Panel and Touchless Hall Station Operating Panels (1) per floor.

Warranty/ Interim maintenance

Proposal shall include 12 months construction/warranty maintenance with 24 hour minor adjustment callback service included. Each unit to receive 12 months of coverage from equipment turnover.

Proposal shall include Interim, maintenance PM costs per month, per unit, to maintain existing elevator equipment under a full preventative maintenance agreement during the modernization process. When elevators are removed from service for the modernization, interim PM responsibilities will end. It is the intent of the owner to suspend/cancel existing PM service and award Modernization and interim PM responsibilities to the same vendor.

DOCUMENT 14 21 01-2

GEARED TRACTION ELEVATOR MODERNIZATION - APPENDIX

Appendix: Clarifications

All new elevator equipment provided shall meet applicable ASME A17.1 code requirements. Any provisions of codes applicable to out-of-scope items shall be the Purchaser's responsibility. Cost of any future code changes adopted prior to permitting and completion are excluded.

The existing cab and entrance dimensions, which may not meet current ADA or stretcher access rules, will be retained as is

All proposals to include inspections and testing as required by the applicable jurisdiction. However, any re-testing required due to other trades' failures to complete their work or tests in a timely manner will be billed at our regular billing rates.

The ASME code limits changes to the empty car weight + capacity of each elevator to 5% of the originally installed value. If past or proposed changes result in a change to the weight or system pressure (for hydraulic) greater than 5% above the original design values, the cost of any engineering and of any required modifications to the elevator system or structure shall be extra to this proposal scope and pricing. If this situation is discovered during the engineering process, "Awarded Contractor" will notify purchaser and recommend an alternate design or other changes.

Asbestos: Notwithstanding anything contained to the contrary within this bid or contract, "Awarded Contractor's" work shall not include any abatement or disturbance of asbestos containing material (ACM) or presumed asbestos containing materials (PACM). Any work in a regulated area as defined by Section 1910 or 1926 of the Federal OSHA regulations is excluded from "Awarded Contractor's" scope of work without an applicable change order to reflect the additional costs and time. In accordance with OSHA requirements, the Customer shall inform contractor and its employees who will perform work activities in areas which contain ACM and/ or PACM of the presence and location of ACM and/or PACM in such areas which may be contacted during work before entering the area. Other than as expressly disclosed in writing, Customer warrants that contractors work area at all times meets applicable OSHA permissible exposure limits (PELs). Contractor shall have the right to discontinue its work in any location where suspected ACM or PACM is encountered or disturbed. Any asbestos removal or abatement, or delays caused by such, required in order for contractor to perform its work shall be the Customer's sole responsibility and expense. After any removal or abatement, customer shall provide documentation that the asbestos has been abated from the contractor work area and air clearance reports shall be made available upon request prior to the start of contractor work.

Site Requirements & Work by Other Trades

Owner reserves the right to Request a turnkey proposal but base bid does not include any of these requirements

“Awarded Contractor” is to perform a detailed site survey, upon award, to determine all applicable items as listed in this section that are needed in either Franklin Tower or Harbor Terrace. Contractor is to provide a detailed list of items needed to Owner (PHA) or its designated representative, with 30 days.

Level of compliance and need in each building may vary from each other or this list. This is a list of requirements only to comply with current code/jurisdictional elevator safety requirement

The work described below is a summary of work to be performed by others (“Work by Other Trades”) that may be required in conjunction with the elevator modernization performed by contractor (the “Work”). Purchaser shall provide any and all building electrical, structural and mechanical system upgrades required for code compliance, life safety, and proper equipment installation and operation. The Authorities Having Jurisdiction (AHJ) may require additional remedial or preparatory work. All required remedial or preparatory work shall be performed by properly licensed trade contractors in compliance with applicable codes and based on a schedule of performance that allows for uninterrupted progress of the Work. Under no circumstances shall “Awarded Contractor” be responsible for any cost associated with the performance of remedial work by others. Purchaser shall provide the following unless specifically included in contractor’s Work:

1. ELECTRICAL

- A properly rated three phase fused disconnect switch, externally operable and lockable in the open position, located as required by code. Accommodate any increases in motor size or feeder loads.
- A dedicated 110 VAC fused disconnect switch, externally operable and lockable in the open position adjacent to the machine room door for cab lighting and ventilation, located as required by code.
- Shunt-trip disconnect if fire sprinklers are present in machine room or hoistway.
- GFI 120 VAC convenience outlets in machine room and pit.
- Separate outlet in the pit area if a sump pump is installed.
- Telephone line service brought to the elevator machine room for emergency communication device.
- Any required RF shielding of TV or radio transmitters, antennae and/or wave-guides.
- Conduit with pull boxes from each elevator bank to any remote fire control or communication panels specified.
- Provide a separate 15-amp, 115 VAC fused service with ground (powered by building emergency power system, when available) for “Awarded Contractor” 24/7 Emergency Communications, when specified. Must include the means to disconnect each service and lock-off in the “open” position (NFPA 70 article 620.22 and 620.53 or CEC article 38.22 and 38.53).
- Roof lighting – reference electrical drawings and specifications for more info.
- Electrical provisions for new mechanical equipment - - reference electrical drawings and specifications for more info.
- Electrical provisions for new Car Sanitization Air Filtration System – 1 per car.
- Electrical provisions for new Car Sanitization UV Light System – 1 per car.

If required by building code: standby/emergency power, sufficiently sized to provide power of permanent characteristics to each elevator’s disconnect, simultaneously, upon loss of regular power, including feeders, transfer switches and auxiliary contact signal outputs to elevator controllers.

2. MACHINE ROOM

- A code-compliant machine room. Provide or maintain fire rating as required by building code.
- Fire-rated door for access into the machine room. Door shall be self-closing and self-locking, operable from inside the room without the use of a key.
- Independent ventilation or an air conditioning system for the elevator machine room, to assure temperature is maintained between 65 degrees and 95 degrees Fahrenheit – reference electrical drawings and specifications for more info, and coordinate with electrician in field as required. Coordinate Location in field with Owner.
- Fire extinguisher inside machine room.
- Minimum clear machine room height of 7'-0”.
- Suitable lighting that provides a minimum of 19 ftc at floor.
- Removal of any non-elevator related equipment and materials from within the machine room and proper disposal of oil and other hazardous or non-hazardous substances and materials.

3. HOISTWAY

- A code-compliant hoistway, constructed in accordance with “Awarded Contractor’s” requirements and specifications. Provide or maintain fire rating as required by building code.
- Patching of all holes in hoistway walls with fire rated material.
- Beveling all ledges within hoistway measuring over 4”.
- Removal of any non-elevator related equipment and materials from within the hoistway and proper disposal of oil and other hazardous or non-hazardous substances and materials.
- A guarded light fixture and light switch in pit. Switch must be located 42” above the lowest landing floor level.
- A means of displacing water located in the pit and containing and disposing of oil, chemicals, and other substances in compliance with environmental laws and regulations (“Awarded Contractor” assumes no responsibility for discharge of oil, chemicals, and other substances into storm water systems, sanitary sewer systems, retention ponds, etc.). Elevator hoistway ventilation to the outside atmosphere as required by building code.

4. FIRE SERVICE

- Fire alarm smoke detectors with wiring and relays in the machine room terminating at elevator controller.
- Fire alarm initiating devices must be located in front of each elevator entrance as well as in the machine room and at the top of the hoistway.

Where sprinklers exist in the machine room and/or hoistway, a fire alarm initiating device within 12” of each sprinkler head.

5. ACCESS INTEGRATION/SECURITY

- Card Readers are not applicable to this project.
- Any required software to ensure proper communication between “Awarded Contractor” control system(s) and building system(s) shall be the responsibility of others.
- A designated 115V 15A circuit is required at each of the remote monitoring stations.
- “Awarded Contractor” recommends a minimum 100 Mbit/s Ethernet for each of the following application(s): Integrated Touchscreen/Keypad Destination Operating Panels, Monitoring System, Multi-Media Equipment.
- Each cab shall be equipped with security camera integral to the building security camera system. Coordinate product and system requirements with owner.

6. COUNTERWEIGHTING

- Proposals are based upon the existing car to counterweight weight ratio being consistent with elevator industry standards. This is defined as the counterweight weight being equal to the empty car weight plus 40%. The actual assemblies will be weighed during the modernization process. If modifications are required to correct the existing weight balance, these modifications will be provided at additional cost.

7. RK1 FUSES AND CIRCUIT BREAKERS

- Fuses are to be current limiting class RK1 or equivalent. Circuit breakers are to have current limiting characteristics equivalent to RK1 fuses. Provisions of these fuses are the responsibility of others, not “Awarded Contractor”.

8. GENERAL

- Access to the building to perform the Work and for deliveries with dry, protected storage adjacent to the hoistway.
- Cutting of existing walls, floors and finishes, together with all repairs made necessary by such cutting or changes, e.g. cutting of lobby walls for flush hall fixtures and removal of encroaching lobby features such as wall-mounted ashtrays. Removal, replacement, and/or repair of any mirrors, millwork, plaster, stone or other special hall finishes.
- All work of other trades must be complete and ready at time of first elevator inspection, or elevator will not be released for operation by the AHJ. If the AHJ does allow temporary operation under a Temporary Operating Inspection (TOI), any associated costs shall be Purchaser’s responsibility.
- Our tender is based on suitable site conditions, material and tooling storage space, and bathroom access being available on site.
- Safe working environment must be provided and supported by provision for adequate entrance protection, means of hoisting, hoistway dividing screens, and protection of floors walls and doors etc.
- Emergency evacuation procedures to be clearly defined where required. Subject to site survey and actions agreed.
- Any portion of the Work that is subject to the permissions of local authorities beyond the elevator permits must be identified to “Awarded Contractor”. Responsibility for permits to be agreed. Permits and appropriate signage indicating any changes to pedestrian access routes for building users must be in place prior to start of the Work.
- Elevator installation methods requires the integrity of the existing Safety Gear and Overspeed protection devices, and are therefore subject to verification of suitability prior to commencement of the work. Any remedial work required or alternative solution is not included in this tender.

SECTION 260000

GENERAL ELECTRICAL REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Basic Electrical Requirements specifically applicable to Divisions 26, 27 and 28 Sections.

1.02 REFERENCES

- A. ANSI/NFPA 70 - National Electrical Code.
- B. ANSI C2 - National Electrical Safety Code.
- C. ANSI/NFPA 101 - Life Safety Code.

1.03 RELATED REQUIREMENTS

- A. Conditions of the Contract and Division 1 - General Requirements, apply to all work, including work of this Division. Examine all contract documents for requirements affecting this work.

1.04 SUBMITTALS

- A. Submit under provisions of Division 01.
- B. Submit shop drawings and product data grouped to include complete submittals of related systems, products, and accessories in a single submittal.
- C. Mark dimensions and values in units to match those specified.
- D. Provide fixture schedule, lighting drawings, panelboard schedules and single line or risers diagram(s) to supplier for assistance in pricing as applicable. Contractor shall receive one set of black line drawings for reproduction from the engineer for this purpose.

1.05 REGULATORY REQUIREMENTS

- A. Conform to applicable local, State and Federal Building Code for the State of Maine.
- B. Electrical: Conform to NFPA 70, NFPA72, NFPA 99, NFPA 101, ANSI C2, 2 FM, UL, and applicable ASTM and ANSI Standards.
- C. Contractor shall visit the site to become familiar with all existing conditions affecting this work. No claim shall be recognized for extra compensation due to failure of contractor to familiarize himself/herself with the conditions and extent of proposed work.
- D. Obtain permits and request inspections by local authority having jurisdiction.

1.06 PROJECT/SITE CONDITIONS

- A. Install Work in locations shown on Drawings, unless prevented by Project conditions.

- B. Prepare drawings showing proposed rearrangement of Work to meet Project conditions, including changes to Work specified in other Sections. Obtain permission of Engineer before proceeding.

1.08 TEMPORARY LIGHT AND POWER

- A. Temporary light and power shall be installed and maintained by the Electrical Contractor for use by all trades for the duration of construction complete with all wiring, switches, protective devices and similar equipment as may be required. Arrangement for the temporary service with the Power Company is the responsibility of the Electrical Contractor. Power bills will be paid by the General Contractor. Provide 120/208 volt or 120/240 volt 100 ampere, drop box similar to standard CMP detail 980-31.1.4. Provide 15-20 watt self ballasted compact fluorescent, lamps with plastic "cages" as needed. or 4 foot twin lamp (T8) fluorescent tamper-proof, gasketed and water-tight as required.

1.09 CONTRACT DRAWINGS AND SPECIFICATIONS

- A. It is to be understood that drawings accompanying these specifications are intended to show general arrangement and extent of work to be done, but exact location and arrangement of all components shall be determined as work progresses. Anything shown on the drawings and not specifically mentioned in specifications or vice versa shall be considered as required in both.
- B. Locations of equipment, and materials, etc., as given on drawings are approximate unless dimensioned. It shall be understood they are subject to such modifications as may be found necessary or desirable at time of installation in order to meet any structural conditions. Such changes shall be made by the contractor without extra charges.
- C. Because of small scale drawings, all required offsets, etc., as may be required to clear work of other Contractors, may not be shown. Contractor, however, shall provide all necessary offsets, etc., as required to complete the installation of their work and not conflict with that of others.
- D. It is the intention that wiring systems shall be complete and fully operational. The contractor shall identify system components during the bid process that clearly constitute conditions that would cause the system to be incomplete. Clarification: The remedy to these discrepancies shall be communicated by the engineer to all bidders or included as an addenda.

1.10 MATERIALS AND LABOR

- A. Bidders for this work shall carefully examine the Plans and Specifications, as the Contractor shall be required to furnish all materials and labor necessary to deliver to the Owner a complete system installed in full accordance with Local State and Federal laws. The system shall be furnished as specified, tested, and turned over to the Owner in perfect operating condition.
- B. All materials shall be new and of best quality of their respective kinds. Workmanship in all respects shall be of highest grade and all construction shall be done according to best practices of the trade. Materials shall be warrantied directly by the manufacturer.
- C. Contractor shall provide, when required for review of Engineer, labeled samples of any material or equipment specified herein or proposed to be used on this project.
- D. Where words "furnish", "provide" or "install" are mentioned, either singly or in combination,

these words are hereby interpreted to mean "furnish and install" or "provide and install," including all materials complete with all connections, supplemental devices, accessories and appurtenances, unless specifically otherwise noted. These words are likewise hereby interpreted as being prefixed to all materials, equipment, and apparatus hereinafter mentioned, either in abbreviated or schedule information.

1.11 PROTECTION OF WORK AND MATERIALS

- A. Contractors shall be responsible for the care and protection of all materials delivered and labor performed until the completion of the work.
- B. Cap all uncompleted lines, raceways, and ducts until ready for final connections, or future work as indicated.
- C. All portions of the work liable to damage by weather or by those engaged on the project, must be securely protected by temporary, but substantial covering which must be maintained in position until Engineer authorizes removal.

1.12 REPLACEMENTS

- A. In the event of damage to any equipment or materials, immediately make all repairs and replacements necessary to the approval of the Engineer at no additional cost to the Owner.

1.13 SAFETY REGULATIONS

- A. All work to be performed and/or installed shall conform to all requirements of the Occupational Safety and Health Act (OSHA) of 1970 and all Amendments thereto.

1.14 INSURANCE

- A. The Contractor shall purchase and maintain all Workmen's Compensation Insurance, Public Liability and Property Damage Insurance during the progress of the work and until completion and acceptance of the entire project by the Owner.

1.15 QUALITY ASSURANCE/CONTROL OF INSTALLATION

- A. Monitor quality control over suppliers, manufacturers, Products, services, site conditions, and workmanship, to produce Work of specified quality.
- B. Comply fully with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from Engineer before proceeding.
- D. Comply with specified standards as a minimum quality for the Work except when more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Perform work using persons qualified to produce workmanship of specified quality.
- F. Secure Products in place with positive anchorage devices designed and sized to withstand stresses, vibration, and physical distortion or disfigurement.

1.16 SCHEDULE OF MATERIALS AND EQUIPMENT

- A. As soon as practicable, and before commencement of installation of any material or equipment, a complete schedule of materials and equipment proposed for installation shall be submitted for review. Schedule shall also include a list of all proposed subcontractors. Partial or incomplete lists will not be considered. Any materials, fixtures, and equipment not conforming to specifications may be rejected. Also see Section 01300, Submittals.
- B. Orders for purchase of any devices, material, conduit, etc., or other equipment shall not be placed until this schedule is reviewed.

1.17 UNDERWRITER'S APPROVALS

- A. All electrical materials and equipment shall bear label of Underwriter's Laboratories, shall be listed by them in their list of electrical fittings and shall be approved by them for purpose for which they are to be used, unless materials and equipment are of a type for which Underwriter's Laboratories does not list or provide label service.

1.18 SUBSTITUTIONS

- A. Where the specifications allow the substitution of a product for that which has been specified, said substitution must be reviewed by the Engineer and shall be equivalent in all respects to that which is specified. The Engineer's decision shall be obtained on all questions as follows, and his/her judgment shall be final and binding on all parties.
- B. Reference in the specifications or on the drawings to any product, material, fixture, form or type of construction, etc., by proprietary name, manufacturer, make or catalog number, shall be interpreted as establishing a standard of quality or design and shall not be construed as limiting competition. The Contractor may, at his/her option, use any fully equivalent substitute provided written review by the Engineer is first obtained indicating acceptance of the equality of the substitute preferred.
- C. For materials or equipment which are supplied with integral or factory applied finish, the colors of same shall be considered in evaluating substitutions.
- D. For the purpose of avoiding conflicts with other trades, contracts, and adjoining work where more than one (1) article, device, material, fixture, form or type of construction, etc., is referred to by proprietary name, manufacturer, make or catalog number, the first named shall be used as the basis of design and details. The cost of any changes of approved equivalent item shall be borne by the Contractor requesting such change.

1.19 RECORD DRAWINGS

- A. During construction, the Contractor shall keep an accurate record of all deviations to the installation of the work as indicated on the drawings. Upon completion of the work, the Contractor shall furnish a copy of this record to the Engineer, on a black line of the original which will be available from the Engineer. Submit record drawings before requesting final payment.

1.20 MANUFACTURER'S REPRESENTATIVE

- A. At appropriate times, or as directed by the Engineer, provide the services of a competent factory trained Engineer or Technician of the particular manufacturer of equipment or item involved, to inspect, adjust, and place in proper operating condition any and all such items of manufacture. No additional compensation shall be allowed Contractors for such service.

1.21 MANUFACTURERS' INSTRUCTIONS, AND OPERATION AND MAINTENANCE DATA

- A. Provide for each item of equipment or apparatus furnished, a complete set of printed instructions obtained from the manufacturer covering proper operation, care, lubrication, cleaning, servicing, adjustment, etc., together with any special safety instructions.
- B. Manufacturers' data shall further include performance data (time current curves, where applicable), complete parts lists, recommended spare parts lists, and wiring diagrams.
- C. Data shall be arranged in complete sets, properly indexed and marked.
- D. Data shall include complete set of shop drawings.
- E. Material shall first be submitted in preliminary fashion for review by Engineer. After approval, Contractor shall submit two (2) copies in bound volumes to the Engineer for distribution.
- F. Provide contacts for service agencies for all major system components.

1.22 GUARANTEES

- A. An item becomes "defective" when it ceases to conform to this Contract Document. Guarantees beginning on the date of issuance of the Owner's final payment, or certificate of substantial completion, with Owner taking occupancy or beneficial use thereafter.
- B. Upon completion of the work and before applying for final payment, furnish a written guarantee, stating that the work complies with the provisions of codes listed herein and the local enforcing authorities, and that it will be free from defects of material and workmanship for the required guarantee period. Guarantee shall further state that the Contractor will, at his own expense, repair and/or replace any of his material and work which may become defective during the time of guarantee, together with other work damaged as a consequence of such defects. All manufacturers written warranties shall apply to materials. Warranties other than that of the manufacturer are not acceptable.
- C. The guarantee period shall be one (1) year except when longer periods are indicated for specific equipment.
- D. All materials in Division 26 where a written warranty is published shall require the warranty to be offered by the product manufacturer.

PART 2 PRODUCTS

Not used.

PART 3 EXECUTION

3.01 CONNECTION TO EQUIPMENT

- A. The Contractor shall be responsible for proper wiring and raceway connections to equipment, make sure of alignment, both initially and under operating conditions, and provide proper supports, brackets, means of expansion, etc., to make sure that no excessive stresses are applied to equipment. Raceways shall be run to the equipment and alignment checked before final bolting and fastening.
- B. At the request of the Engineer, dismantle equipment connections to demonstrate proper installation and make such corrections necessary without additional compensation for disassembly, re-connection, or the required corrective work.

- C Equipment shall be installed in such a manner as to permit disconnecting for service and repairs without the necessity of rigging.

3.02 CLOSING IN UNINSPECTED WORK

- A General: Do not cover up or enclose work until it has been properly and completely inspected and approved. Engineer may waive this requirement by written permission.
- B Noncompliance: Should any of the work be covered up or enclosed prior to all required inspections and approvals, uncover the work as required, and after it has been completely inspected and approved, make all repairs and replacements with such materials as are necessary to the approval of the Engineer and at no additional cost to the Owner.

3.03 CLEANING OF SYSTEMS

- A All wiring systems shall be thoroughly cleaned prior to initial operation and in accordance with manufacturer's instructions for equipment to be furnished and/or installed.
- B Furnish all detergents, solvents, cleaning compounds, tools, etc., required in connection with cleaning operations.
- C Thoroughly clean all exposed portions of all equipment, remove all labels, and wipe clean with a damp rag.

3.04 TESTING, BALANCING, AND ADJUSTING

- A Electrical loads shall be balanced on all phase legs to a tolerance of plus or minus 10 percent. Include testing circuits for shorts to ground. Measure grounding system resistance. Correct all deficiencies. Provide all test equipment.

3.05 INSTRUCTIONS

- A On completion of the job, Contractor shall provide competent technicians to thoroughly instruct the Owner's representative in the care and operation of the system. The total period of instruction shall not exceed 2 hours and be performed in a minimum of one interval. The time of instruction shall be arranged with the Owner. The Electrical subcontractor shall be present and participate in the Owner's instruction.

3.06 FIRESTOPPING

- A Firestopping shall be performed in accordance with Specification Section "Firestopping". All penetrations of fire-rated assemblies including walls and floors by electrical system components (conduits, cables, trays, etc.) shall be firestopped as specified. Coordinate size, location and type of sleeves as required by firestopping systems.

*** END OF SECTION ***

SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

- 1. Building wires and cables rated 600 V and less.
- 2. Connectors, splices, and terminations rated 600 V and less.

B. Related Requirements:

- 1. Section 271500 "Communications Horizontal Cabling" for cabling used for voice and data circuits.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

PART 2 - PRODUCTS

2.1 CONDUCTORS AND CABLES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

- 1. General Cable Technologies Corporation.
- 2. Southwire Incorporated.
- 3. The Okonite Company.

- B. Copper Conductors: Comply with NEMA WC 70/ICEA S-95-658.

- C. Conductor Insulation: Comply with NEMA WC 70/ICEA S-95-658 for Type THHN-2-THWN-2.

- D. Multiconductor Cable: Comply with NEMA WC 70/ICEA S-95-658 for Metal Clad cable, Type MC or SO cable.

2.2 CONNECTORS AND SPLICES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

1. AFC Cable Systems, Inc.
2. Gardner Bender.
3. Hubbell Power Systems, Inc.
4. Ideal Industries, Inc.
5. IIsco; a branch of Bardes Corporation.
6. NSi Industries LLC.
7. O-Z/Gedney; a brand of the EGS Electrical Group.
8. 3M; Electrical Markets Division.
9. Tyco Electronics.

- B. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.

2.3 SYSTEM DESCRIPTION

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NFPA 70.

PART 3 - EXECUTION

3.1 CONDUCTOR MATERIAL APPLICATIONS

- A. Feeders: Copper for feeders smaller than No. 4 AWG; copper or aluminum for feeders No. 4 AWG and larger. Solid for No. 10 AWG and smaller; stranded for No. 8 AWG and larger.
- B. Branch Circuits: Copper. Solid for No. 12 AWG and smaller; stranded for No. 10 AWG and larger.
- C. All conductor sizes shown on drawings are for copper unless noted otherwise.

3.2 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS

- A. Service Entrance: Type THHN-2-THWN-2, single conductors in raceway.
- B. Feeders: Type THHN-2-THWN-2, single conductors in raceway.
- C. Exposed Branch Circuits, Including in Crawlspace: Type THHN-2-THWN-2, single conductors in raceway.
- D. Branch Circuits Concealed in Ceilings, Walls, and Partitions: Metal Clad Cable, Type MC.
- E. Branch Circuits Concealed in Concrete, below Slabs-on-Grade, and Underground: Type THHN-2-THWN-2, single conductors in raceway.
- F. Cord Drops and Portable Appliance Connections: Type SO, hard service cord with stainless-steel, wire-mesh, strain relief device at terminations to suit application.

3.3 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors unless otherwise indicated.
- B. Complete raceway installation between conductor and cable termination points according to Section "Raceways and Boxes for Electrical Systems" prior to pulling conductors and cables.
- C. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- D. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips that will not damage cables or raceway.
- E. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.

3.4 CONNECTIONS

- A. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A-486B.
- B. Make splices, terminations, and taps that are compatible with conductor material.
- C. Wiring at Outlets: Install conductor at each outlet, with at least 6 inches of slack.

3.5 IDENTIFICATION

- A. Identify and color-code conductors and cables according to Section "Identification for Electrical Systems."
- B. Identify each spare conductor at each end with identity number and location of other end of conductor, and identify as spare conductor.

3.6 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:
 - 1. After installing conductors and cables and before electrical circuitry has been energized, test service entrance and feeder conductors for compliance with requirements.
 - 2. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
- B. Test and Inspection Reports: Prepare a written report to record the following:
 - 1. Procedures used.
 - 2. Results that comply with requirements.
 - 3. Results that do not comply with requirements and corrective action taken to achieve compliance with requirements.

- C. Cables will be considered defective if they do not pass tests and inspections.

END OF SECTION 260519

SECTION 260526 - GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes: Grounding systems and equipment.
- B. Section includes grounding systems and equipment, plus the following special applications:
 - 1. Underground distribution grounding.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

1.4 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with UL 467 for grounding and bonding materials and equipment.

PART 2 - PRODUCTS

2.1 CONDUCTORS

- A. Insulated Conductors: Copper or tinned-copper wire or cable insulated for 600 V unless otherwise required by applicable Code or authorities having jurisdiction.
- B. Bare Copper Conductors:
 - 1. Solid Conductors: ASTM B 3.
 - 2. Stranded Conductors: ASTM B 8.
 - 3. Tinned Conductors: ASTM B 33.
 - 4. Bonding Cable: 28 kcmil, 14 strands of No. 17 AWG conductor, 1/4 inch (6 mm) in diameter.
 - 5. Bonding Conductor: No. 4 or No. 6 AWG, stranded conductor.
 - 6. Bonding Jumper: Copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches (41 mm) wide and 1/16 inch (1.6 mm) thick.
 - 7. Tinned Bonding Jumper: Tinned-copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches (41 mm) wide and 1/16 inch (1.6 mm) thick.

- C. Grounding Bus: Predrilled rectangular bars of annealed copper, 1/4 by 4 inches (6.3 by 100 mm) in cross section, with 9/32-inch (7.14-mm) holes spaced 1-1/8 inches (28 mm) apart. Stand-off insulators for mounting shall comply with UL 891 for use in switchboards, 600 V. Lexan or PVC, impulse tested at 5000 V.

2.2 CONNECTORS

- A. Listed and labeled by an NRTL acceptable to authorities having jurisdiction for applications in which used and for specific types, sizes, and combinations of conductors and other items connected.
- B. Bolted Connectors for Conductors and Pipes: Copper or copper alloy, pressure type with at least two bolts.
 - 1. Pipe Connectors: Clamp type, sized for pipe.
- C. Welded Connectors: Exothermic-welding kits of types recommended by kit manufacturer for materials being joined and installation conditions.
- D. Bus-bar Connectors: Mechanical type, cast silicon bronze, solderless compression-type wire terminals, and long-barrel, two-bolt connection to ground bus bar.

2.3 GROUNDING ELECTRODES

- A. Ground Rods: Copper-clad steel; 3/4 inch by 10 feet.
 - 1. Termination: Factory-attached No. 4/0 AWG bare conductor at least 48 inches (1200 mm) long.
 - 2. Backfill Material: Electrode manufacturers recommended material.

PART 3 - EXECUTION

3.1 APPLICATIONS

- A. Conductors: Install solid conductor for No. 8 AWG and smaller, and stranded conductors for No. 6 AWG and larger unless otherwise indicated.
- B. Underground Grounding Conductors: Install bare tinned-copper conductor, No. 2/0 AWG minimum.
 - 1. Bury at least 24 inches (600 mm) below grade.
 - 2. Duct-Bank Grounding Conductor: Bury 12 inches (300 mm) above duct bank when indicated as part of duct-bank installation.
- C. Grounding Bus: Install in electrical and telephone equipment rooms, in rooms housing service equipment, and elsewhere as indicated.
 - 1. Install bus on insulated spacers 2 inches (50 mm) minimum from wall, 6 inches (150 mm) above finished floor unless otherwise indicated.
 - 2. Where indicated on both sides of doorways, route bus up to top of door frame, across top of doorway, and down to specified height above floor; connect to horizontal bus.

- D. Conductor Terminations and Connections:
 - 1. Pipe and Equipment Grounding Conductor Terminations: Bolted connectors.
 - 2. Underground Connections: Welded connectors except at test wells and as otherwise indicated.
 - 3. Connections to Ground Rods at Test Wells: Bolted connectors.
 - 4. Connections to Structural Steel: Welded connectors.

3.2 GROUNDING UNDERGROUND DISTRIBUTION SYSTEM COMPONENTS

- A. Comply with IEEE C2 grounding requirements.
- A. Install insulated equipment grounding conductors with all feeders and branch circuits.
- B. Air-Duct Equipment Circuits: Install insulated equipment grounding conductor to duct-mounted electrical devices operating at 120 V and more, including air cleaners, heaters, dampers, humidifiers, and other duct electrical equipment. Bond conductor to each unit and to air duct and connected metallic piping.
- C. Water Heater, Heat-Tracing, and Antifrost Heating Cables: Install a separate insulated equipment grounding conductor to each electric water heater and heat-tracing cable. Bond conductor to heater units, piping, connected equipment, and components.
- D. Metal Poles Supporting Outdoor Lighting Fixtures: Install grounding electrode and a separate insulated equipment grounding conductor in addition to grounding conductor installed with branch-circuit conductors.

3.4 INSTALLATION

- A. Grounding Conductors: Route along shortest and straightest paths possible unless otherwise indicated or required by Code. Avoid obstructing access or placing conductors where they may be subjected to strain, impact, or damage.
- B. Ground Rods: Drive rods until tops are 2 inches (50 mm) below finished floor or final grade unless otherwise indicated.
 - 1. Interconnect ground rods with grounding electrode conductor below grade and as otherwise indicated. Make connections without exposing steel or damaging coating if any.
 - 2. For grounding electrode system, install at least three rods spaced at least one-rod length from each other and located at least the same distance from other grounding electrodes, and connect to the service grounding electrode conductor.
- C. Bonding Straps and Jumpers: Install in locations accessible for inspection and maintenance except where routed through short lengths of conduit.
 - 1. Bonding to Structure: Bond straps directly to basic structure, taking care not to penetrate any adjacent parts.
 - 2. Bonding to Equipment Mounted on Vibration Isolation Hangers and Supports: Install bonding so vibration is not transmitted to rigidly mounted equipment.
 - 3. Use exothermic-welded connectors for outdoor locations; if a disconnect-type connection is required, use a bolted clamp.

D. Grounding and Bonding for Piping:

1. Metal Water Service Pipe: Install insulated copper grounding conductors, in conduit, from building's main service equipment, or grounding bus, to main metal water service entrances to building. Connect grounding conductors to main metal water service pipes; use a bolted clamp connector or bolt a lug-type connector to a pipe flange by using one of the lug bolts of the flange. Where a dielectric main water fitting is installed, connect grounding conductor on street side of fitting. Bond metal grounding conductor conduit or sleeve to conductor at each end.
2. Water Meter Piping: Use braided-type bonding jumpers to electrically bypass water meters. Connect to pipe with a bolted connector.

E. Bonding Interior Metal Ducts: Bond metal air ducts to equipment grounding conductors of associated fans, blowers, electric heaters, and air cleaners. Install bonding jumper to bond across flexible duct connections to achieve continuity.

3.5 LABELING

- A. Comply with requirements in Section 260553 "Identification for Electrical Systems" for instruction signs. The label or its text shall be green.

3.6 FIELD QUALITY CONTROL

A. Perform tests and inspections.

1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.

B. Tests and Inspections:

1. After installing grounding system but before permanent electrical circuits have been energized, test for compliance with requirements.
2. Inspect physical and mechanical condition. Verify tightness of accessible, bolted, electrical connections with a calibrated torque wrench according to manufacturer's written instructions.

C. Grounding system will be considered defective if it does not pass tests and inspections.

D. Prepare test and inspection reports.

E. Report measured ground resistances that exceed the following values:

1. Power and Lighting Equipment or System with Capacity of 500 kVA and less: 10 ohms.

F. Excessive Ground Resistance: If resistance to ground exceeds specified values, notify Architect promptly and include recommendations to reduce ground resistance.

END OF SECTION 260526

SECTION 261900
SUPPORTING DEVICES

PART 1 GENERAL

1.01 WORK INCLUDED

- A. Conduit and equipment supports.
- B. Fastening hardware.

1.02 RELATED WORK

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

PART 2 PRODUCTS

2.01 MATERIAL

- A. Support Channel: Galvanized or painted steel.
- B. Hardware: Corrosion resistant.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Fasten hanger rods, conduit clamps, and outlet and junction boxes to building structure using pre-cast insert system, expansion anchors, beam clamps.
- C. Anchors and Fasteners
 - 1) Concrete Structural Elements: Use pre-cast insert system, expansion anchors, powder actuated anchors and preset inserts.
 - 2) Steel Structural Elements: Use beam clamps, steel ramset fasteners, and welded fasteners.
 - 3) Concrete Surfaces: Use self-drilling anchors and expansion anchors.
 - 4) Hollow Masonry, Plaster, and Gypsum Board Partitions: Use toggle bolts and hollow wall fasteners.
 - 5) Solid Masonry Walls: Use expansion anchors and preset inserts.
 - 6) Sheet Metal: Use sheet metal screws.
 - 7) Wood Elements: Use wood screws.
- D. Do not fasten supports to piping, ductwork, mechanical equipment, or conduit.
- E. Do not use power-actuated anchors.
- F. Do not drill structural steel members.

- G. Fabricate supports or trapeze hangers from structural steel or steel channel, rigidly welded or bolted to present a neat appearance. Use hexagon head bolts with spring lock washers under all nuts.
- H. In wet locations install free-standing electrical equipment on concrete pads.
- I. Install surface-mounted cabinets and panelboards with minimum of four anchors. Provide steel channel supports to stand cabinet one inch off wall.

*** END OF SECTION ***

SECTION 262726 - WIRING DEVICES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Receptacles, receptacles with integral GFCI, and associated device plates.
 - 2. Weather-resistant receptacles.
 - 3. Snap switches.
 - 4. Cord and plug sets.

1.3 DEFINITIONS

- A. EMI: Electromagnetic interference.
- B. GFCI: Ground-fault circuit interrupter.
- C. Pigtail: Short lead used to connect a device to a branch-circuit conductor.
- D. RFI: Radio-frequency interference.
- E. TVSS: Transient voltage surge suppressor.
- F. UTP: Unshielded twisted pair.

1.4 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Receptacles for Owner-Furnished Equipment: Match plug configurations.
 - 2. Cord and Plug Sets: Match equipment requirements.

1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.6 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

PART 2 - PRODUCTS**2.1 MANUFACTURERS**

- A. Manufacturers' Names: Shortened versions (shown in parentheses) of the following manufacturers' names are used in other Part 2 articles:
1. Cooper Wiring Devices; Division of Cooper Industries, Inc. (Cooper).
 2. Hubbell Incorporated; Wiring Device-Kellems (Hubbell).
 3. Leviton Mfg. Company Inc. (Leviton).
 4. Pass & Seymour/Legrand (Pass & Seymour).
- B. Source Limitations: Obtain each type of wiring device and associated wall plate from single source from single manufacturer.

2.2 GENERAL WIRING-DEVICE REQUIREMENTS

- A. Wiring Devices, Components, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NFPA 70.
- C. Devices that are manufactured for use with modular plug-in connectors may be substituted under the following conditions:
1. Connectors shall comply with UL 2459 and shall be made with stranding building wire.
 2. Devices shall comply with the requirements in this Section.

2.3 STRAIGHT-BLADE RECEPTACLES

- A. Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 Configuration 5-20R, UL 498, and FS W-C-596.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:

2.4 GFCI RECEPTACLES

- A. General Description:
1. Straight blade, non-feed-through type.
 2. Comply with NEMA WD 1, NEMA WD 6, UL 498, UL 943 Class A, and FS W-C-596.
 3. Include indicator light that shows when the GFCI has malfunctioned and no longer provides proper GFCI protection.
- B. Duplex GFCI Convenience Receptacles, 125 V, 20 A:
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:

2.5 CORD AND PLUG SETS**A. Description:**

1. Match voltage and current ratings and number of conductors to requirements of equipment being connected.
2. Cord: Rubber-insulated, stranded-copper conductors, with Type SOW-A jacket; with green-insulated grounding conductor and ampacity of at least 130 percent of the equipment rating.
3. Plug: Nylon body and integral cable-clamping jaws. Match cord and receptacle type for connection.

2.6 TOGGLE SWITCHES

A. Comply with NEMA WD 1, UL 20, and FS W-S-896.

B. Switches, 120/277 V, 20 A:

1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:

2.7 WALL-BOX DIMMERS

A. Control: Continuously adjustable slider; with single-pole or three-way switching. Comply with UL 1472.

2.8 WALL PLATES

A. Single and combination types shall match corresponding wiring devices.

1. Plate-Securing Screws: Metal with head color to match plate finish.
2. Material for Finished Spaces: **Stainless Steel**.
3. Material for Unfinished Spaces: **Stainless Steel**.
4. Material for Damp Locations: Cast aluminum with spring-loaded lift cover and listed and labeled for use in wet and damp locations.

B. Wet-Location, Weatherproof Cover Plates: NEMA 250, complying with Type 3R, weather-resistant, die-cast aluminum with lockable cover.

2.9 FLOOR SERVICE FITTINGS

A. Type: Modular, flush-type, dual-service units suitable for wiring method used.

B. Compartments: Barrier separates power from voice and data communication cabling.

C. Service Plate: Round, die-cast aluminum with satin finish.

D. Power Receptacle: NEMA WD 6 Configuration 5-20R, gray finish, unless otherwise indicated.

E. Voice and Data Communication Outlet: Two modular, keyed, color-coded, RJ-45 jacks for UTP cable complying with requirements in Section 271500 "Communications Horizontal Cabling."

2.10 FINISHES

A. Device Color:

1. Wiring Devices Connected to Normal Power System: As selected by Architect unless otherwise indicated or required by NFPA 70 or device listing.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Comply with NECA 1, including mounting heights listed in that standard, unless otherwise indicated.

B. Coordination with Other Trades:

1. Protect installed devices and their boxes. Do not place wall finish materials over device boxes and do not cut holes for boxes with routers that are guided by riding against outside of boxes.
2. Keep outlet boxes free of plaster, drywall joint compound, mortar, cement, concrete, dust, paint, and other material that may contaminate the raceway system, conductors, and cables.
3. Install device boxes in brick or block walls so that the cover plate does not cross a joint unless the joint is troweled flush with the face of the wall.
4. Install wiring devices after all wall preparation, including painting, is complete.

C. Conductors:

1. Do not strip insulation from conductors until right before they are spliced or terminated on devices.
2. Strip insulation evenly around the conductor using tools designed for the purpose. Avoid scoring or nicking of solid wire or cutting strands from stranded wire.
3. The length of free conductors at outlets for devices shall meet provisions of NFPA 70, Article 300, without pigtails.

D. Device Installation:

1. Replace devices that have been in temporary use during construction and that were installed before building finishing operations were complete.
2. Keep each wiring device in its package or otherwise protected until it is time to connect conductors.
3. Do not remove surface protection, such as plastic film and smudge covers, until the last possible moment.
4. Connect devices to branch circuits using pigtails that are not less than 6 inches (152 mm) in length.
5. When there is a choice, use side wiring with binding-head screw terminals. Wrap solid conductor tightly clockwise, two-thirds to three-fourths of the way around terminal screw.
6. Use a torque screwdriver when a torque is recommended or required by manufacturer.
7. When conductors larger than No. 12 AWG are installed on 15- or 20-A circuits, splice No. 12 AWG pigtails for device connections.
8. Tighten unused terminal screws on the device.
9. When mounting into metal boxes, remove the fiber or plastic washers used to hold device-mounting screws in yokes, allowing metal-to-metal contact.

- E. Receptacle Orientation:
 - 1. Install ground pin of vertically mounted receptacles down, and on horizontally mounted receptacles to the right.
- F. Device Plates: Do not use oversized or extra-deep plates. Repair wall finishes and remount outlet boxes when standard device plates do not fit flush or do not cover rough wall opening.
- G. Dimmers:
 - 1. Install dimmers within terms of their listing.
 - 2. Install unshared neutral conductors on line and load side of dimmers according to manufacturers' device listing conditions in the written instructions.
- H. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical and with grounding terminal of receptacles on top. Group adjacent switches under single, multigang wall plates.
- I. Adjust locations of floor service outlets and service poles to suit arrangement of partitions and furnishings.

3.2 GFCI RECEPTACLES

- A. Install non-feed-through-type GFCI receptacles where protection of downstream receptacles is not required.

3.3 IDENTIFICATION

- A. Identify each receptacle with panelboard identification and circuit number. Use hot, stamped, or engraved machine printing with black-filled lettering on face of plate, and durable wire markers or tags inside outlet boxes.

3.4 FIELD QUALITY CONTROL

- A. Test straight-blade for the retention force of the grounding blade according to NFPA 99. Retention force shall be not less than 4 oz. (115 g).
- B. Wiring device will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

END OF SECTION 262726

SECTION 283111

DIGITAL, ADDRESSABLE FIRE-ALARM SYSTEM

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. System smoke detectors.
 2. Heat detectors.
 3. Addressable interface device.

1.2 SYSTEM DESCRIPTION

- A. Noncoded, addressable system, with multiplexed signal transmission, dedicated to fire-alarm service only. **Expand existing fire alarm system to include new devices indicated on drawings.**

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For fire-alarm system. Include plans, elevations, sections, details, and attachments to other work.
1. Comply with recommendations in the "Documentation" Section of the "Fundamentals of Fire Alarm Systems" Chapter in NFPA 72.
 2. Include voltage drop calculations for notification appliance circuits.
 3. Include battery-size calculations.
 4. Include performance parameters and installation details for each detector, verifying that each detector is listed for complete range of air velocity, temperature, and humidity possible when air-handling system is operating.
 5. Include plans, sections, and elevations of heating, ventilating, and air-conditioning ducts, drawn to scale and coordinating installation of duct smoke detectors and access to them. Show critical dimensions that relate to placement and support of sampling tubes, detector housing, and remote status and alarm indicators. Locate detectors according to manufacturer's written recommendations.
- C. General Submittal Requirements:
1. Submittals shall be approved by authorities having jurisdiction prior to submitting them to Architect.
 2. Shop Drawings shall be prepared by persons with the following qualifications:

- a. Trained and certified by manufacturer in fire-alarm system design.
- b. NICET-certified fire-alarm technician, Level III minimum.

1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified Installer.
- B. Field quality-control reports.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For fire-alarm systems and components to include in emergency, operation, and maintenance manuals.
- B. Software and Firmware Operational Documentation:
 1. Software operating and upgrade manuals.
 2. Program Software Backup: On magnetic media or compact disk, complete with data files.
 3. Device address list.
 4. Printout of software application and graphic screens.

1.6 QUALITY ASSURANCE

- A. Installer Qualifications: Personnel shall be trained and certified by manufacturer for installation of units required for this Project.
- B. Installer Qualifications: Installation shall be by personnel certified by NICET as fire-alarm Level II technician.
- C. Source Limitations for Fire-Alarm System and Components: Obtain fire-alarm system from single source from single manufacturer. Components shall be compatible with, and operate as, an extension of existing system.
- D. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

1.7 SOFTWARE SERVICE AGREEMENT

- A. Comply with UL 864.
- B. Technical Support: Beginning with Substantial Completion, provide software support for two years.
- C. Upgrade Service: Update software to latest version at Project completion. Install and program software upgrades that become available within two years from date of

Substantial Completion. Upgrading software shall include operating system. Upgrade shall include new or revised licenses for use of software.

1. Provide 30 days' notice to Owner to allow scheduling and access to system and to allow Owner to upgrade computer equipment if necessary.

PART 2 - PRODUCTS

2.1 SYSTEM SMOKE DETECTORS

A. General Requirements for System Smoke Detectors:

1. Comply with UL 268; operating at 24-V dc, nominal.
2. Detectors shall be four-wire type.
3. Integral Addressable Module: Arranged to communicate detector status (normal, alarm, or trouble) to fire-alarm control unit.
4. Base Mounting: Detector and associated electronic components shall be mounted in a twist-lock module that connects to a fixed base. Provide terminals in the fixed base for connection to building wiring.
5. Self-Restoring: Detectors do not require resetting or readjustment after actuation to restore them to normal operation.
6. Integral Visual-Indicating Light: LED type indicating detector has operated and power-on status.

B. Photoelectric Smoke Detectors:

1. Detector address shall be accessible from fire-alarm control unit and shall be able to identify the detector's location within the system and its sensitivity setting.
2. An operator at fire-alarm control unit, having the designated access level, shall be able to manually access the following for each detector:
 - a. Primary status.
 - b. Device type.
 - c. Present average value.
 - d. Present sensitivity selected.
 - e. Sensor range (normal, dirty, etc.).

C. Duct Smoke Detectors: Photoelectric type complying with UL 268A.

1. Detector address shall be accessible from fire-alarm control unit and shall be able to identify the detector's location within the system and its sensitivity setting.
2. An operator at fire-alarm control unit, having the designated access level, shall be able to manually access the following for each detector:
 - a. Primary status.
 - b. Device type.
 - c. Present average value.
 - d. Present sensitivity selected.
 - e. Sensor range (normal, dirty, etc.).

3. Weatherproof Duct Housing Enclosure: NEMA 250, Type 4X; NRTL listed for use with the supplied detector.
4. Each sensor shall have multiple levels of detection sensitivity.
5. Sampling Tubes: Design and dimensions as recommended by manufacturer for specific duct size, air velocity, and installation conditions where applied.
6. Relay Fan Shutdown: Rated to interrupt fan motor-control circuit.

2.2 HEAT DETECTORS

- A. General Requirements for Heat Detectors: Comply with UL 521.
- B. Heat Detector, Combination Type: Actuated by either a fixed temperature of 135 deg F (57 deg C) or a rate of rise that exceeds 15 deg F (8 deg C) per minute unless otherwise indicated.
 1. Mounting: Twist-lock base interchangeable with smoke-detector bases.
 2. Integral Addressable Module: Arranged to communicate detector status (normal, alarm, or trouble) to fire-alarm control unit.

2.3 ADDRESSABLE INTERFACE DEVICE

- A. Description: Microelectronic monitor module, NRTL listed for use in providing a system address for alarm-initiating devices for wired applications with normally open contacts.
- B. Integral Relay: Capable of providing a direct signal to elevator controller to initiate elevator recall or operate Fire/Smoke damper.

PART 3 - EXECUTION

3.1 EQUIPMENT INSTALLATION

- A. Comply with NFPA 72 for installation of fire-alarm equipment.
- B. Install wall-mounted equipment, with tops of cabinets not more than 72 inches (1830 mm) above the finished floor.
- C. Duct Smoke Detectors: Comply with NFPA 72 and NFPA 90A. Install sampling tubes so they extend the full width of duct.
- D. Heat Detectors in Elevator Shafts: Coordinate temperature rating and location with sprinkler rating and location.

3.2 CONNECTIONS

- A. For fire-protection systems related to doors in fire-rated walls and partitions and to doors in smoke partitions, comply with requirements in Section "Door Hardware." Connect hardware and devices to fire-alarm system.

1. Verify that hardware and devices are NRTL listed for use with fire-alarm system in this Section before making connections.
- B. Make addressable connections with a supervised interface device to the following devices and systems. Install the interface device less than 3 feet (1 m) from the device controlled. Make an addressable confirmation connection when such feedback is available at the device or system being controlled.
 1. Alarm-initiating connection to elevator recall system and components.
 2. Supervisory connections at valve supervisory switches.
 3. Supervisory connections at elevator shunt trip breaker.

3.3 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 260553 "Identification for Electrical Systems."
- B. Install framed instructions in a location visible from fire-alarm control unit.

3.4 GROUNDING

- A. Ground fire-alarm control unit and associated circuits; comply with IEEE 1100. Install a ground wire from main service ground to fire-alarm control unit.

3.5 FIELD QUALITY CONTROL

- A. Tests and Inspections:
 1. Visual Inspection: Conduct visual inspection prior to testing.
 - a. Inspection shall be based on completed Record Drawings and system documentation that is required by NFPA 72 in its "Completion Documents, Preparation" Table in the "Documentation" Section of the "Fundamentals of Fire Alarm Systems" Chapter.
 - b. Comply with "Visual Inspection Frequencies" Table in the "Inspection" Section of the "Inspection, Testing and Maintenance" Chapter in NFPA 72; retain the "Initial/Reacceptance" column and list only the installed components.
 2. System Testing: Comply with "Test Methods" Table in the "Testing" Section of the "Inspection, Testing and Maintenance" Chapter in NFPA 72.
 3. Test audible appliances for the public operating mode according to manufacturer's written instructions. Perform the test using a portable sound-level meter complying with Type 2 requirements in ANSI S1.4.
 4. Test audible appliances for the private operating mode according to manufacturer's written instructions.
 5. Test visible appliances for the public operating mode according to manufacturer's written instructions.

6. Factory-authorized service representative shall prepare the "Fire Alarm System Record of Completion" in the "Documentation" Section of the "Fundamentals of Fire Alarm Systems" Chapter in NFPA 72 and the "Inspection and Testing Form" in the "Records" Section of the "Inspection, Testing and Maintenance" Chapter in NFPA 72.

END OF SECTION 283111