2	615 ARNO NE	18/21	2/78	SCH
CLASS OF WORK	ADDRESS	NUMBER OF CARDS	DATE	DESCRIPTION

SCHEDULE OF GAUGES FOR RECTANGULAR DUCT CONSTRUCTION - ALL SITES

Steel U.S. Std. Gauge	Maximum Side, Inches	Type of Transverse Joint Connections	Bracing
26	Up to 12	S, drive, pocket or bar slips, on 7'-0" center.	None.
24	13 to 18	S, drive, pocket or bar slips, on 7'-0" center.	None.
24	19 to 30	S, drive, 1" pocket or 1" bar slips on 7'-0" center.	1 x 1 x 1/8" angles 4' from joint.

PLUMBING FIXTURES SCHEDULE

SYMBOL	DESCRIPTION
P-1	WATER CLOSET: AMERICAN STANDARD "Cadet" Model 2122.059, siphon jet, close-coupled tank, standard Tank and Fittings, with CHURCH No. 5330.022 seat. 3" waste, 2" vent, ½" cw.
P-2	LAVATORY: AMERICAN STANDARD, "Declyn" Model No.0321.026 19" x 17", with Aquarian faucet, pop-up drain. Furnish speed riser supplies with stops, state app'd. trap (1¼" x 1½"). 1¼" p-trap, 1½" waste, 1½" vent, ½" cw & ½" hw. Furnish with mounting frame.
P-3	LAVATORY: AMERICAN STANDARD "Scotian" Model 0360.024 with Aquarian faucet, pop-up drain, 20" x 18". Furnish speed riser supplies with stops, State Approved trap (1¼" x 1½"). 1¼" p-trap, 1½" waste, 1½" vent, ½" cw, ½" hw. Wall hanger, enameled cast iron.
P-4	BATH TUB: ROBINSON & LAMY "Classic" - Integral Bath & Shower Unit with wall surround, 5 ft. length, reinforced fiberglass, plastic, no clg. Right or left outlet as required. Furnish with Symmons D-1-210-XK non-scald Tub & Shower safety mix unit, concealed mixing valve with integral stops, volume control P.B., Tub Spout & Shower head. Color to be white. ½" cw, ½" hw, 1½" vent, 1½" p-trap, 1½" waste, 14" APRON.
P-5	KITCHEN SINK: AMERICAN STANDARD Model No. 7018.013 flat rim countertop sink, enameled cast iron, 4179.016 single lever faucet, 4331.013 crumb cup strainers. Furnish speed riser supplies with stops. State approved trap (1½" x 2"). ½" cw, ½" hw, 1½" vent, 2" waste.

NOTE: This Contractor shall furnish and install all fixtures indicated on the drawings, with all required connections. Each fixture branch riser shall be taken off from the top of branch main, and an air-chamber 12" long (minimum) shall be located above each fixture branch, undiminished thus:



All branches shall be valved and all valves shall be accessible with access provided by this Contractor. All valves shall have unions adjacent.

GRILLE & REGISTER SCHEDULE

SYMBOL	DESCRIPTION
RG	RETURN GRILLE: ANEMOSTAT No. S3HD, steel construction, fixed horizontal fins spaced 3/4". Furnish with baked enamel prime coat finish. Actual sizes as noted on the drawings.
D-2	SIDEWALL REGISTER: KRUEGER Series 800 , with vertical face bars individually adjustable & rear horizontal gang operated, . Actual sizes shall be as noted on the drawings. Furnish with opposed blade damper with slotted adjustment.

MISCELLANEOUS PLUMBING EQUIP. SCHEDULE

SYMBOL	DESCRIPTION
CO	CLEANOUT: SMITH No. 4223, cast iron top, vandalproof screws, galvanized. (for outside installation).
WCO	WALL CLEAN-OUT: SMITH #4470, EXTRA HEAVY BRONZE PLUG
HWH-1	WATER HEATER: Natural gas fired, orificed for operation at 5200 ft. elev., glass-lined tank. Furnish ASME combination T&P relief valve with full size type "K" copper relief drain. 100% safety pilot METALBESTOS type "B" flue. Furnish 5 year warranty. Nos. are NATIONAL.
WRB	WASHER ROUGH-IN BOX: CARUTH recessed water connector box with drain fitting and hose bibbs. Steel case with white finish, Model "A".
WH-1	WALL HYDRANT: SMITH 5510, freezeproof bronze construction.

SYMBOL	MODEL	S/L INPUT	STORAGE CAP.	FLUE
HWH-1	N30S-5R	42,000	30	3"φ

MECHANICAL EQUIPMENT SCHEDULE

SYMBOL	DESCRIPTION
1	FURNACE: AGA approved, orificed for operation at 5300 ft. elevation, direct drive, forced air furnace, natural gas fired. Furnish with replaceable air filters and standard safety controls, including a 100% pilot safety, wall thermostat. LENNOX Model G12D2-55, 55,000 BTUH SL furnace input, 750 cfm at .3" TSP, 120V-1φ-60~, 1/5 HP, ½" acoustic liner in fan compartment.
2	EVAPORATIVE COOLER: Side discharge, drip type unit, adjustable V-belt drive, pads, float valve, 120V-1φ pump, 20 ga.galv. sheet metal covers to close inlet louvers during winter, complete package unit, 2-speed, 2-winding fan motor. Models are ARCTIC CIRCLE.
3	EXHAUST FAN: Recessed ceiling, installation, complete with inlet grille, backdraft damper, roofjack with birdscreen. BROAN Model No. 666, 80 cfm, 120V-1φ-60~.

SYMBOL	MODEL	CFM AT 3/8" SP (HI SPD)	HP	MOTOR
2	3003B-2	2500	1/4	120V-1φ-60~

CITY OF ALBUQUERQUE
The microfilmed of this document is certified to be an accurate copy of the original document as it appears in the files of the BUILDING AND INSPECTION DIVISION
Mary Lou Cooper, City Clerk/Recorder

BARKER-BOL & ASSOCIATES
ARCHITECTS
JOB NO. 74-03
DATE: 2-16-76
REVISED DATE: 4/16/76

LOCKWOOD MODERN CONSTRUCTION COMPANY

SCHEDULES
ARTO ST. & COMANCHE RD. SITE

TURNKEY HOUSING
PROJECT N.M. 1-11-A

M 10

MAY 28 1976
BUILDING SERVICES

PROFESSIONAL ENGINEER
JOHN LYNN
3845
NEW MEXICO
ROBERT E. WIGHTMAN

CITY OF ALBUQUERQUE