



**Richmar Manor #15 Unit Fire Restoration
Quotation for Small Purchase (QSP 17-Q003)
Issue Date: May 9, 2017**

ADDENDUM #2

Issued: May 23, 2017

NOTICE TO QUOTERS:

- A. This Addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.
- B. Offerors are hereby notified that they shall make any necessary adjustment in their estimates on account of this Addendum. It will be construed that each Bidder's documentation is submitted with full knowledge of all modifications and supplemental data specified herein.

Addendum #2

1. Question: My Supplier cannot get a hold of Grade A Rotary Cut White Birch Hollow Core as Specified, Is Grade A Rotary Cut Maple Hollow Core Doors an acceptable alternative?

Response: Yes. Any closed grain white hardwood that can be finished to match the specified trim & base will be acceptable. Our intent was to restore the unit as closely as possible to its original design.

Alternatively, in that white birch doors are not as plentiful as they once were, a painted finished would be acceptable, in which case all frames, base molding and trim would be painted as well.

It should also be noted, since the original door hardware was not present at the time of the walk-thru that the finish is to be bright brass, with the exception of the entry door hardware which is to be reused.

(End of Addendum #2)

#####

Solicitation Inquiries: Craig Bartley

E-Mail: cbartley@lucasmha.org

Phone: 419-254-3497

Section 3 Inquiries to: Martice Bishop

mbishop@lucasmha.org

