



**Collingwood Green Phase 3  
Invitations for Bids (IFB17-B002)  
Issued: September 6, 2017**

---

---

**ADDENDUM #3**

**Issued: September 26, 2017**

---

---

**NOTICE TO PROPOSERS:**

- A. This Addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.
- B. Offerors are hereby notified that they shall make any necessary adjustment in their estimates on account of this Addendum. It will be construed that each Bidder's documentation is submitted with full knowledge of all modifications and supplemental data specified herein.

---

**ADDENDUM NO. 3**

1. To clarify, HUD 2328 and HUD 5372 shall not be required to be submitted with the bid. The awarded Contractor shall be required to submit the required Forms within 3 days of the Notice of Award.
2. Please see the attached Addendum "03" from Berardi + Partners.

**(End of Addendum #3)**

**#####**

**Solicitation Inquiries: Kattie Bond**

E-Mail: [kbond@lucasmha.org](mailto:kbond@lucasmha.org)

Phone: 419-259-9471

**Section 3 Inquiries to:**

[mbishop@lucasmha.org](mailto:mbishop@lucasmha.org)

Phone: 419-259-9441





## ADDENDUM '03'

The Proposal Drawings and Specifications, dated (09/06/2017) for:

Project Name Collingwood Green Phase 3  
Toledo, Ohio

Addendum Date: September 26, 2017

### NOTICE TO CONTRACTORS:

- A. This Addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.
- B. This Addendum is complimentary to and refers to revised drawings issued herewith this document, or provides general narrative for revisions to drawings not necessarily issued with this document.

### Architectural:

1. Sheet A101F:
  - a. two single double hung windows (30x54) labeled as "Q" should be labeled "P".
  - b. double windows labeled as 'R' should be type 'Q'.
  - c. single windows designated as type 'U' to be type 'O'.
2. Sheet A101D: two windows on the south elevation of Building D as double windows 6'8" wide but the door schedule calls for a single window that is 3'0" wide. Please advise. *To be window type Q.*
3. Sheet A201B: Exterior elevations show the window on the north east corner of Building B as double windows 6'8" wide but the door schedule calls for a single window 2'6" wide. Please advise *To be window type Q.*

### Contractor Question Responses:

1. Looking at the Civil Site plans, is there a key or legend that indicates what areas are to be paved Asphalt - Light/Heavy Duty?  
*Shown on page 2/17, heavy duty and light duty concrete shown will be alternately bid with heavy duty and light duty asphalt.*

END OF ADDENDUM 03