

Addendum 3

2017-9-1

Concrete Grinding and Resurfacing

Questions and Answers

Question: Is there any particular product you guys want used to fill holes and cracks?

Answer: There is no brand name product specified or required. The specifications appear below. Prep and application must be per manufacturers' instructions.

- The fill material for **cracks exceeding ½"** in width must be a polymer concrete product designed for concrete resurfacing/repair. Silicone or rubber caulk products are not acceptable.
- An elastomeric caulk may be used as fill material for **cracks up to ½"** in width. Silicone or rubber caulk products are not acceptable.

Question: My second question just to clarify is, is the ten days for completion the entire project or ten days for each project site?

Answer: We will extend the contract performance period to fifteen (15) calendar days rather than ten. This term is for completion of all items included in the contract.