MECHANICAL EQUIPMENT SCHEDULE

MARK	DESCRIPTION	MANUFACTURER	MODEL NO.	REMARKS
C1	CONDENSER (OUTDOOR UNIT)	MITSUBISHI	MXZ-3C24NA2-U1	MAX. 25 AMP OVERTURN PROTECTION @ 240V
C2	CONDENSER (OUTDOOR UNIT)	MITSUBISHI	MXZ-3C30NA2-U1	MAX. 25 AMP OVERTURN PROTECTION @ 240V
C3	CONDENSER (OUTDOOR UNIT)	MITSUBISHI	MXZ-4C36NA2-U1	MAX. 25 AMP OVERTURN PROTECTION @ 240V
C4	CONDENSER (OUTDOOR UNIT)	MITSUBISHI	MXZ-5C42NA2-U1	REQUIRES INSTALLATION OF #8 CONDUCTOR OR EQ. WITH MAX. 40 AMP OVERTURN PROTECTION @ 240V
C5	CONDENSER (OUTDOOR UNIT)	MITSUBISHI	MUZ-GL12NA-U1	MAX. 15 AMP OVERTURN PROTECTION @ 240V
AH1	AIR HANDLER (INDOOR UNIT)	MITSUBISHI	MSZ-GL06NA-U1	¼" LIQUID X ⅜" SUCTION REFRIGERATION LINE SETS
AH2	AIR HANDLER (INDOOR UNIT)	MITSUBISHI	MSZ-GL12NA-U1	¼" LIQUID X ⅜" SUCTION REFRIGERATION LINE SETS
AH3	AIR HANDLER (INDOOR UNIT)	MITSUBISHI	MSZ-GL15NA-U1	¼" LIQUID X ½" SUCTION REFRIGERATION LINE SETS

FLOOR PLAN LEGEND

AH1 — AIR HANDLER (INDOOR UNIT)

C1 — CONDENSER (OUTDOOR UNIT)

SCHEDULE LEGEND

- TAKE CORRECTIVE ACTION
- ACTION MAY BE REQUIRED BUT SPECIFIC DWELLING UNITS NOT IDENTIFIED. SEE UNIT PRICE SECT OF SPECIFICATIONS.
- UNABLE TO SURVEY UNIT. WORK IDENTIFIED BASED ON ASSUMPTIONS AND MAY BE ADJUSTED VIA UNIT PRICES.
- WORK TO BE INCLUDED IN BASE BID BUT MAY BE REMOVED BY ALTERNATE. REFER TO SPECIFICATIONS FOR CLARITY.

GENERAL NOTES

1. PLANS DEPICT TYPICAL UNIT CONFIGURATIONS. ACTUAL CONFIGURATION MAY VARY WITHIN INDIVIDUAL UNITS.
2. REFER SHEET A2.1 FOR ADDL BLDG PLAN CONFIGURATIONS.
3. LOCATION OF MECH EQUIP IS DIAGRAMMATIC & MUST BE FIELD VERIFIED.
4. CONDENSER MOUNTING BRACKETS MAY REQUIRE ALTERATION TO WORK WITH NEW EQUIPMENT.
5. SHOULD CONTRACTOR DETECT ERRORS OR OMISSIONS IN THE SCOPE OF WORK LEGEND, HE SHOULD CONSULT ARCHITECT FOR CLARIFICATION.

SCOPE OF WORK SCHEDULE

BUILDING LOCATIONS AND TYPES — 27 BUILDINGS, 120 UNITS

| | DESCRIPTION OF WORK | BRAHAN AVENUE (8 BLDGS, 32 UNITS) | | | |