

**BID NO. 2019-003-000-50-4430016:**

**HEATING AND AIR CONDITIONING PREVENTATIVE MAINTENANCE AND REPAIR SERVICES**

**ADDENDUM NO. 5**

**April 22, 2019**

Please add these two (2) pages to Section 5 (Form of Bid) of Bid No. 2019-003-000-50-4430016:

1. **Additional Pages to Section 5 (FORM OF BID):**

Supply costs for Base Contract and Extension Years 1 and 2 for the Acid Neutralizing Media for Gas-fired Hot Water Condensing Boilers. The 20 Acid Neutralizing Media tanks are included in the Equipment Maintenance Specifications of the bid. The winning Contractor shall remove the media from the existing canister for each boiler system and replenish the canister with new media according to the Fall and Spring preventative maintenance schedule for each respective boiler.

Complete the following information and include one (1) copy of Addendum No. 5 with the Form of Bid.

Company: \_\_\_\_\_

By: \_\_\_\_\_

Print Name & Title: \_\_\_\_\_

Date: \_\_\_\_\_

Company Address: \_\_\_\_\_