



420 S 8th Street
Louisville, KY 40203

ADDENDUM NO. 4

**SANITARY SEWER MODIFICATIONS
760 SOUTH HANCOCK STREET
PROPOSAL # 1485**

To: All Plan Holders

From: Norma Ward
Director, Capital Improvements Department
Louisville Metro Housing Authority
420 South Eighth Street
Louisville, Kentucky 40203

Date: June 11, 2019

The purpose of this Addendum is to clarify the requirements of the specifications and plans.

The bidders are governed by the information in this Addendum as if included in the original bid documents.

This Addendum does hereby become a part of the Contract Documents.

Each bidder shall acknowledge receipt of this Addendum in the space provided in the Bid Form.

This Addendum consists of one (1) page (8 1/2" x 11") and one (1) drawings (8 1/2" x 11").

This Addendum is installed on the Louisville Metro Housing Authority's Electronic Procurement System.

A. GENERAL

1. The **BID DATE** is **10:00 a.m.**, Tuesday **June 18, 2019**.
2. Response to questions:
 - a. Will PVC pipe be allowed for the drain piping?
Answer: PVC will be allowed per code acceptance

B. PLANS

1. A partial plan of Sheet P3.0, Plan 02 is attached. It shows a stud wall separating spaces 122 and 123.

END OF ADDENDUM #4

