

July 18, 2019

This Addendum to the Quote for Small Purchase (QSP) serves to notify all interested proposers of clarifications and or changes to QSP No. SP19007, and becomes part of this QSP. Proposers are required to acknowledge receipt of this addendum in their proposal. If not acknowledged, the proposal may be considered “non-responsive.”

A. The Agency received the following 9 questions:

QUESTION:

1. Can you provide the model and serial numbers of equipment on roof and/or mezzanine area at 5326 E. Pine Ave?

ANSWER:

CU1- Model #24ABB360A520 Serial # 0910e09390
AHU1- 58MXB080-f-10120 Serial# 2607A02741 Filter: (20/24/2)x1 No belt
CU2- Model # 24ABB360A520 Serial # 0910E09399
AHU2- Model #58MXB080-F-10120 Serial # 2908A00788 Filter: (20/24/2)x1 No belt
Server Room Indoor- Model # DALA-1032-CO-S Serial # 2010-0820-A Filter: (20/25/4)x2
(16/25/4)x2 Belt: (A42)x2
Server Room Condensing Unit- Model # DARC-1732 Serial # 2010-821-A
Evap Cooler1- Model # TBA450-G Serial# C0305500097
Evap Cooler2- Model # TBA450-G Serial# C0311090027
Evap Cooler3- Model # TBA450-G Serial# C0311090013
Rooftop Package Unit 1- Model # GPG12300701A Serial# 0407553699 (16/25/1)x1
(15/25/1)x1 No Belt
Rooftop Package Unit 2- Model # RRKA-A048CK10E Serial # 1R6819ADAAF290315
(16/25/1)x1 (15/25/1)x1 No Belt

QUESTION:

2. What are the filter sizes and quantity for the 5326 E. Pine Ave. location?

ANSWER:

CU1- Model #24ABB360A520 Serial # 0910e09390
AHU1- 58MXB080-f-10120 Serial# 2607A02741 Filter: (20/24/2)x1 No belt
CU2- Model # 24ABB360A520 Serial # 0910E09399
AHU2- Model #58MXB080-F-10120 Serial # 2908A00788 Filter: (20/24/2)x1 No belt
Server Room Indoor- Model # DALA-1032-CO-S Serial # 2010-0820-A Filter:
(20/25/4)x2
(16/25/4)x2 Belt: (A42)x2
Server Room Condensing Unit- Model # DARC-1732 Serial # 2010-821-A

Evap Cooler1- Model # TBA450-G Serial# C0305500097
Evap Cooler2- Model # TBA450-G Serial# C0311090027
Evap Cooler3- Model # TBA450-G Serial# C0311090013
Rooftop Package Unit 1- Model # GPG12300701A Serial# 0407553699 (16/25/1)x1
(15/25/1)x1 No Belt
Rooftop Package Unit 2- Model # RRKA-A048CK10E Serial # 1R6819ADAAF290315
(16/25/1)x1 (15/25/1)x1 No Belt

QUESTION:

3. What are the belt sizes and quantity for 5326 E. Pine Ave. location?

ANSWER:

CU1- Model #24ABB360A520 Serial # 0910e09390
AHU1- 58MXB080-f-10120 Serial# 2607A02741 Filter: (20/24/2)x1 No belt
CU2- Model # 24ABB360A520 Serial # 0910E09399
AHU2- Model #58MXB080-F-10120 Serial # 2908A00788 Filter: (20/24/2)x1 No belt
Server Room Indoor- Model # DALA-1032-CO-S Serial # 2010-0820-A Filter:
(20/25/4)x2
(16/25/4)x2 Belt: (A42)x2
Server Room Condensing Unit- Model # DARC-1732 Serial # 2010-821-A
Evap Cooler1- Model # TBA450-G Serial# C0305500097
Evap Cooler2- Model # TBA450-G Serial# C0311090027
Evap Cooler3- Model # TBA450-G Serial# C0311090013
Rooftop Package Unit 1- Model # GPG12300701A Serial# 0407553699 (16/25/1)x1
(15/25/1)x1 No Belt
Rooftop Package Unit 2- Model # RRKA-A048CK10E Serial # 1R6819ADAAF290315
(16/25/1)x1 (15/25/1)x1 No Belt

QUESTION:

4. Can you provide information on the Humidifier (Mfg., model, and serial number) for 5326 E. Pine Ave. location?

ANSWER:

Condair, Model# Nortec MES2-010/208-277/1 REM CE, Serial# 2298314.

QUESTION:

5. How many lamps for the 5326 E. Pine Ave. location, and can you provide more information on the on lamps?

ANSWER:

Not Applicable at this time.

QUESTION:

6. Can you provide water filter information for 5326 E. Pine Ave. location?

ANSWER:

Not applicable at this time.

QUESTION:

7. Can you provide information on the oil and oil filter for 5326 E. Pine Ave. location?

ANSWER:

Not applicable at this time.

QUESTION:

8. Are there cell deck pads in the breeze air coolers, and if so, when was the last time they were changed? (Cell deck pads under normal circumstances only need to be changed every 3-5 years).

ANSWER:

Yes, date of last change is unknown, approximately 4 years old. Recommend replacement.

QUESTION:

9. What is the current contract amount for each location? What is your current hourly rate?

ANSWER:

The Agency does not provide contract values as part of the solicitation.

Lyric Aguigam
Procurement Coordinator
laguigam@fresnohousing.org
Fresno Housing Authority
1331 Fulton Street
Fresno, California 93721
559-443-8437
(800) 735-2929 TTY
www.fresnohousing.org

Vibrant Communities. Quality Housing. Engaged Residents.

