



JACKSONVILLE HOUSING AUTHORITY (JHA)

Addendum Number: Three (3)

Proposal Number: CN-006-20

Title of proposal: Blodgett Villas Roof Replacement – 10 Buildings

This addendum is hereby incorporated into the contract documents for the above project.

This addendum is for the purpose of clarifications and amendments.

Dated: August 7, 2020

The following items are clarifications, additions and revisions to, and shall take precedence over the original specifications dated as issued for proposal, July 1, 2020.

Questions Received:

1. Is GC License required. What is needed to do business in the State of Florida? – A GC license is not required but a roofing contractor license is required. The solicitation documents include what is needed to do business with our Agency, if you have questions about doing business in the State of Florida please refer to the State of Florida website at <https://dos.myflorida.com/sunbiz/>.
2. Is all the metal wall flashing being replaced even if it's in good condition? Yes, all wall flashing is replaced.
3. Is new gutter being installed on all roof eaves or just existing locations? New gutters and downspouts should be installed on all roofs as specified in Attachment A2 of this solicitation.
4. Downspouts are not currently 20 feet max per SOW, are we to add additional? Yes, every 20 feet.
5. Can we reuse the existing flue vents or are they being replaced? They need to be replaced.

Bidder's Signature

Title

Company Name



Date

If this addendum affects bid pricing for a bid previously submitted, the previously submitted bid will be returned unopened. If this addendum does not affect bid prices for a bid previously submitted, the acknowledgement may be mailed/delivered in a sealed envelope labeled with the proposal number and addenda number and must be received in Purchasing **PRIOR** to the bid opening.

DO NOT FAX THIS FORM.

This addendum is issued for the information of the above titled project and will be part of the contract.
