


**Roof Curb Clip Calculations
for
Lennox RTUs
2017 Florida Building Code**

For:

Curbs Plus, Inc.
8767 Alabama Hwy (GA Hwy 151)
Ringgold, GA 30736

March 2018



**March Adams & Associates, Inc.
310 Dodds Avenue
Chattanooga, Tennessee 37404
Job #: 18-098**

Clip capacity Information for use by Design Professionals in determining the number and location of the clips required to secure mechanical equipment to the roof curb - maximum wind speed 175 mph.



CALCULATIONS per the 2017 Florida Building Code

Notes:

- 1) All page and section references in this calculation to wind loads are to the referenced Building Code, U.N.
- 2) All references for Cold Form Steel Calculations are to the *North American Specification for the Design of Cold-Formed Steel Structural Members* - 2001 Edition

Design Note: The 14 ga clips were checked for different types of units and were found to be adequate for equipment hold down. Clips are to be installed as shown on the Hold Down Clip Locations sketch and attached using (4) #14 Tek's to the curb and to the unit.

Wind Forces per Section 1609

- Wind_Code = "ASCE 7-10" <---per Section 1609.1.1 of 2017 Florida Building Code
- Risk_Category = "II" <---per Table 1.5-1 of ASCE 7-10
- V_W = 175·mph <---basic wind speed, ASCE 7-10 Figures 26.5-1A, 26.5-1B and 26.5-1C dependent on Risk Category
- K_d := 0.9 <---wind directional factor, see ASCE 7-10 Section 26.6 and Table 26.6-1
- Exposure = "C" <---exposure category, see ASCE 7-10 Section 26.7.3
- α = 9.5 <---Table 26.9-1, 3-second gust speed power law exponent
- z_g = 900 ft <---Table 26.9-1, nominal height of the atmospheric boundary layer
- z_{min} = 15 ft <---Table 26.14, exposure constant
- H_R = 30 ft <---roof height
- z := max(z_{min}, H_R) z = 30 ft <---mean roof height or min, used in calcs for MWFRS and Comp and Cladding
- $$K_z := 2.01 \left(\frac{z}{z_g} \right)^{\frac{2}{\alpha}} \quad K_z = 0.98 \quad \text{---Velocity pressure exposure coefficient, Table 27.3-1 ASCE 7-10}$$
- K_{zt} = 1 <---topographic factor, see ASCE 7-10 Section 26.8.2
- $$q_z := 0.00256 \cdot K_z \cdot K_{zt} \cdot K_d \left(\frac{V_W}{\text{mph}} \right)^2 \cdot \text{psf} \quad \text{---basic velocity pressure, ASCE 7-10, Section 30.3.2 and Eq. 30.3-1}$$
- q_z = 69.3·psf q_h := q_z

Clip Values

Assume unit gauge and material match clip

$$F_u = 54 \cdot \text{ksi} \quad \leftarrow \text{---tensile strength of steel}$$

$$\Omega_{\text{screw}} := 3 \quad \leftarrow \text{---safety factor for screw connections, see Section E4}$$

$$G_{\text{aclip}} = 14 \quad \leftarrow \text{---gauge of clip}$$

$$L_{\text{clip}} = 6 \cdot \text{in} \quad \leftarrow \text{---length of clip}$$

$$t_c = 0.0713 \cdot \text{in} \quad \leftarrow \text{---thickness of clip}$$

$$P_{\text{ns}} := \begin{cases} E_{4.3.1_1} \leftarrow 4.2 \cdot \left(t_c^3 \cdot d_{14} \right)^{\frac{1}{2}} \cdot F_u \\ E_{4.3.1_2} \leftarrow 2.7 \cdot t_c \cdot d_{14} \cdot F_u \\ \min(E_{4.3.1_1}, E_{4.3.1_2}) \end{cases}$$

$$P_{\text{ns}} = 2158.97 \cdot \text{lb}f \quad \leftarrow \text{---nominal shear strength, per screw- Eq. E4.3.1-1 and E4.3.1-2}$$

$$P_{\text{as}} := \frac{P_{\text{ns}}}{\Omega_{\text{screw}}} \quad P_{\text{as}} = 719.66 \cdot \text{lb}f \quad \leftarrow \text{---allowable shear on material, per screw}$$

$$e_{\text{min}} := \frac{P_{\text{ns}}}{t_c \cdot F_u} \quad e_{\text{min}} = 0.56 \cdot \text{in} \quad \leftarrow \text{---minimum end distance, E4.2 and E4.3.2}$$

$$s_{\text{pmin}} := 3 \cdot d_{14} \quad s_{\text{pmin}} = 0.75 \cdot \text{in} \quad \leftarrow \text{---minimum screw spacing, E4.1}$$

$$\text{edge}_{\text{min}} := 1.5d_{14} \quad \text{edge}_{\text{min}} = 0.38 \cdot \text{in} \quad \leftarrow \text{---minimum edge distance, E4.2}$$

Screw Values

$$N_{\text{screws}} = 4 \quad \leftarrow \text{---number of screws per clip}$$

$$V_{14_{\text{ult}}} = 2584 \cdot \text{lb}f \quad \leftarrow \text{---ultimate shear value on 1/4" Tek screw}$$

$$V_{14_{\text{all}}} := \frac{0.8V_{14_{\text{ult}}}}{\Omega_{\text{screw}}} \quad V_{14_{\text{all}}} = 689 \cdot \text{lb}f \quad \leftarrow \text{---allowable shear, E4.3.3}$$

$$V_{\text{clip}} := \min(V_{14_{\text{all}}}, P_{\text{as}}) \cdot N_{\text{screws}} \quad \leftarrow \text{---total allowable shear on clip}$$

$$V_{\text{clip}} = 2756.27 \cdot \text{lb}f$$

Bending

$$\Omega_b := 1.67 \quad \text{<---safety factor for bending, C3.1.1}$$

$$F_y = 38 \text{ ksi} \quad \text{<---yield stress of steel}$$

$$S_e := \frac{t_c \cdot L_{clip}^2}{6} \quad S_e = 0.43 \cdot \text{in}^3 \quad \text{<---effective section modulus}$$

$$M_n := S_e \cdot F_y \quad \text{<---effective yield moment, Eq C3.1.1-1}$$

$$M_a := \frac{M_n}{\Omega_b} \quad \text{<---allowable bending in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in}$$

**Equipment: Lennox
Models: KCA, KGA, KHA 024-072 and
LCH, LGH 036-072 (Worst Case)
for use with Curbs Plus Curb #:
LENNOX T/K-SERIES/LGH-LCH 024-072**

sub _{matrix1} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KCA-024"	83.25	45	35.38	18	495	79.13	40.88
	"KCA-030"	83.25	45	35.38	18	496	79.13	40.88
	"KCA-036"	83.25	45	35.38	18	499	79.13	40.88
	"KCA-048"	83.25	45	35.38	18	535	79.13	40.88
	"KCA-060"	83.25	45	35.38	18	565	79.13	40.88
sub _{matrix2} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KGA-024"	83.25	45	35.38	18	532	79.13	40.88
	"KGA-030"	83.25	45	35.38	18	533	79.13	40.88
	"KGA-036"	83.25	45	35.38	18	534	79.13	40.88
	"KGA-048"	83.25	45	35.38	18	571	79.13	40.88
	"KGA-060"	83.25	45	35.38	18	600	79.13	40.88
sub _{matrix3} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KHA-024"	83.25	45	35.38	18	532	79.13	40.88
	"KHA-030"	83.25	45	35.38	18	533	79.13	40.88
	"KHA-036"	83.25	45	35.38	18	535	79.13	40.88
	"KHA-048"	83.25	45	35.38	18	556	79.13	40.88
	"KHA-060"	83.25	45	43.38	18	647	79.13	40.88
sub _{matrix4} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"LCH-036"	83.25	45	35.38	18	532	79.13	40.88
	"LCH-048"	83.25	45	35.38	18	562	79.13	40.88
	"LCH-060"	83.25	45	43.38	18	648	79.13	40.88
	"LCH-072"	83.25	45	43.38	18	726	79.13	40.88
	"LGH-036"	83.25	45	35.38	18	567	79.13	40.88
	"LGH-048"	83.25	45	35.38	18	599	79.13	40.88
	"LGH-060"	83.25	45	43.38	18	685	79.13	40.88
"LGH-072"	83.25	45	43.38	18	762	79.13	40.88	

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 96.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_max} = 45 \cdot \text{in}$ <---outside width of unit
 $H_{u_max} = 43.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross_Section = "Square"
 $Weight_{max} = 780 \text{ lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 355.33 \text{ lbf} \quad \text{<---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)}$$

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 3817.8 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_max} \cdot L_{u_max}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 3126.97 \text{ lbf}$

$$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}} \quad P_{vLwind} = 1840 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right) \quad \text{<---uplift per clip}$$

$Uplift_L = 813.38 \cdot \text{lbf}$

Design Forces (continued_

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(L_{u_max}, W_{u_max}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 1784.95 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 402.19 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 188.99 \text{ lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 813.38 \text{ lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 813 \text{ lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756 \text{ lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \text{ in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 3.76 \text{ kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \text{ kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.24 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 83.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 45 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 35.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $Weight_{min} = 495 \cdot \text{lb}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 2693.11 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 2704.63 \text{ lbf}$

$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vLwind} = 1059 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 469.87 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 1455.73 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 309 \cdot \text{lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 190.49 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 469.87 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 469.87 \cdot \text{lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 2.17 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.08 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

**Equipment: Lennox
Models: KCA-M, KGA-M, KHA-M 024-072
and LCH-M, LGH-M 036-072 (Worst Case)
for use with Curbs Plus Curb #:
LENNOX T/K-SERIES/LGH-LCH 024-072**

sub_matrix1 =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KCA-024-M"	83.25	45	35.38	18	607	79.13	40.88
	"KCA-030-M"	83.25	45	35.38	18	608	79.13	40.88
	"KCA-036-M"	83.25	45	35.38	18	611	79.13	40.88
	"KCA-048-M"	83.25	45	35.38	18	647	79.13	40.88
	"KCA-060-M"	83.25	45	35.38	18	680	79.13	40.88
sub_matrix2 =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KGA-024-M"	83.25	45	35.38	18	631	79.13	40.88
	"KGA-030-M"	83.25	45	35.38	18	633	79.13	40.88
	"KGA-036-M"	83.25	45	35.38	18	635	79.13	40.88
	"KGA-048-M"	83.25	45	35.38	18	682	79.13	40.88
	"KGA-060-M"	83.25	45	35.38	18	712	79.13	40.88
sub_matrix3 =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KHA-024-M"	83.25	45	35.38	18	644	79.13	40.88
	"KHA-030-M"	83.25	45	35.38	18	645	79.13	40.88
	"KHA-036-M"	83.25	45	35.38	18	647	79.13	40.88
	"KHA-048-M"	83.25	45	35.38	18	669	79.13	40.88
	"KHA-060-M"	83.25	45	43.38	18	770	79.13	40.88
sub_matrix4 =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"LCH-036-M"	83.25	45	35.38	18	714	79.13	40.88
	"LCH-048-M"	83.25	45	35.38	18	748	79.13	40.88
	"LCH-060-M"	83.25	45	43.38	18	856	79.13	40.88
	"LCH-072-M"	83.25	45	43.38	18	904	79.13	40.88
	"LGH-036-M"	83.25	45	35.38	18	735	79.13	40.88
	"LGH-048-M"	83.25	45	35.38	18	778	79.13	40.88
	"LGH-060-M"	83.25	45	43.38	18	883	79.13	40.88
"LGH-072-M"	83.25	45	43.38	18	930	79.13	40.88	

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 83.25 \cdot \text{in}$	<---outside length of unit
$W_{u_max} = 45 \cdot \text{in}$	<---outside width of unit
$H_{u_max} = 43.38 \cdot \text{in}$	<---height of unit from top of curb
Cross_Section = "Square"	
$Weight_{max} = 930 \text{ lbf}$	<---installation weight of mechanical unit.

Design Forces

Dead Forces

$$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 372 \text{ lbf} \quad \text{<---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)}$$

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$	<---factor for rooftop structures and equipment with A_f less than 0.1Bh, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$	<---vertical projected area of the rooftop unit, ASCE 7-10
$F_h := q_h \cdot (GC_r) \cdot A_f$	<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
$F_h = 3302.15 \text{ lbf}$	

Wind uplift on unit

$GC_r := 1.5$	<---factor for rooftop structures and equipment with A_r less than 0.1BL, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_r := W_{u_max} \cdot L_{u_max}$	<---horizontal projected area of the rooftop unit, ASCE 7-10
$F_v := q_h \cdot (GC_r) \cdot A_r$	<---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
$F_v = 2704.63 \text{ lbf}$	

$$P_{vL.wind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}} \quad P_{vL.wind} = 1591 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$$N_{clipsL} = 2 \quad \text{<---number of clips on long side (Length) of unit}$$

$$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vL.wind} - 0.6P_{dead}}{N_{clipsL}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_L = 684.13 \cdot \text{lbf}$$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(I_{u_max}, W_{u_max}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 1784.95 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 465 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 241.8 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 684.13 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 684 \cdot \text{lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756 \cdot \text{lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 3.16 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.17 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 83.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 45 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 35.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $Weight_{min} = 607 \cdot \text{lb}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 2693.11 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 2704.63 \text{ lbf}$

$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vLwind} = 1059 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 456.43 \cdot \text{lbf}$

Design Forces (continued_

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 1455.73 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 309 \cdot \text{lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 163.61 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 456.43 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 456.43 \cdot \text{lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 2.11 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.07 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Equipment: Lennox
Model: K-Series 090 F.P. (Worst Case)
for use with Curbs Plus Curb
LENNOX K-SERIES 090 F.P.

Unit	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
UnitData =	"KCA-090"	96.25	45	43.38	21	767	92.13	40.88
	"KGA-090"	96.25	45	43.38	21	781	92.13	40.88
	"KCA-090-M"	96.25	45	43.38	21	873	92.13	40.88
	"KGA-090-M"	96.25	45	43.38	21	911	92.13	40.88

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 96.25 \cdot \text{in}$	<---outside length of unit
$W_{u_max} = 45 \cdot \text{in}$	<---outside width of unit
$H_{u_max} = 43.38 \cdot \text{in}$	<---height of unit from top of curb
Cross_Section = "Square"	
$Weight_{max} = 911 \text{ lbf}$	<---installation weight of mechanical unit.

Design Forces

Dead Forces

$$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 425.13 \text{ lbf} \quad \text{<---minimum dead load per linear foot acting vertically on curb. } L_{cg} \text{ (distance to center of gravity assumed at mid point)}$$

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$	<---factor for rooftop structures and equipment with A_f less than 0.1Bh, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$	<---vertical projected area of the rooftop unit, ASCE 7-10
$F_h := q_h \cdot (GC_r) \cdot A_f$	<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
$F_h = 3817.8 \text{ lbf}$	

Wind uplift on unit

$GC_r := 1.5$	<---factor for rooftop structures and equipment with A_r less than 0.1BL, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_r := W_{u_max} \cdot L_{u_max}$	<---horizontal projected area of the rooftop unit, ASCE 7-10
$F_v := q_h \cdot (GC_r) \cdot A_r$	<---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
$F_v = 3126.97 \text{ lbf}$	

$$P_{vL_wind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}} \quad P_{vL_wind} = 1840 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vL_wind} - 0.6P_{dead}}{N_{clipsL}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_L = 792.44 \cdot \text{lbf}$$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \text{<---factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(I_{u_max}, W_{u_max}) \quad \text{<---vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \text{<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 1784.95 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 402.19 \text{ lbf} \quad \text{<---vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \text{<---number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_W = 147.11 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad \text{Uplift} = 792.44 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 792 \cdot \text{lbf} \quad \text{<---actual shear on clip}$$

$$V_{clip} = 2756 \cdot \text{lbf} \quad \text{<---allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \text{<---moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 3.67 \cdot \text{kip} \cdot \text{in} \quad \text{<---actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \text{<---allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.22 \quad \text{<---interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 96.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 45 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 43.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $Weight_{min} = 767 \cdot \text{lb}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg
 (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with Af less than 0.1Bh,
 Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 3817.8 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with Ar less than 0.1BL,
 Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 3126.97 \text{ lbf}$

$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vLwind} = 1840 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 812.6 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \text{<---factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \text{<---vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \text{<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 1784.95 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 402 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \text{<---number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_W = 187.43 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad \text{Uplift} = 812.6 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 812.6 \cdot \text{lbf} \quad \text{<---actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \text{<---allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \text{<---moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 3.76 \cdot \text{kip} \cdot \text{in} \quad \text{<---actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \text{<---allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.24 \quad \text{<---interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

**Equipment: Lennox
Models: KCA, KGA, KHA 092-150
and LCH, LGH 092-150 (Worst Case)
for use with Curbs Plus Curb
LENNOX K-SERIES/LGH-LCH 092-150**

sub_matrix1 =	{	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
		"KCA-092"	99.25	58.13	43.38	24.5	942	94.75	53.63
		"KCA-102"	99.25	58.13	43.38	24.5	962	94.75	53.63
		"KCA-120"	99.25	58.13	43.38	24.5	1002	94.75	53.63
		"KCA-150"	99.25	58.13	43.38	24.5	1093	94.75	53.63
		"KGA-092"	99.25	58.13	43.38	24.5	990	94.75	53.63
		"KGA-102"	99.25	58.13	43.38	24.5	1011	94.75	53.63
		"KGA-120"	99.25	58.13	43.38	24.5	1051	94.75	53.63
"KGA-150"	99.25	58.13	43.38	24.5	1141	94.75	53.63		
sub_matrix2 =	{	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
		"KHA-092"	99.25	58.13	43.38	24.5	1052	94.75	40.88
		"KHA-102"	99.25	58.13	43.38	24.5	1084	94.75	53.63
		"KHA-120"	99.25	58.13	43.38	24.5	1151	94.75	53.63
sub_matrix3 =	{	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
		"LCH-092"	99.25	58.13	43.38	24.5	1120	94.75	53.63
		"LCH-102"	99.25	58.13	43.38	24.5	1126	94.75	53.63
		"LCH-120"	99.25	58.13	43.38	24.5	1162	94.75	53.63
		"LCH-150"	99.25	58.13	43.38	24.5	1202	94.75	53.63
		"LGH-092"	99.25	58.13	43.38	24.5	1168	94.75	53.63
		"LGH-102"	99.25	58.13	43.38	24.5	1175	94.75	53.63
		"LGH-120"	99.25	58.13	43.38	24.5	1210	94.75	53.63
"LGH-150"	99.25	58.13	43.38	24.5	1249	94.75	53.63		

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 99.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_max} = 58.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_max} = 43.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross_Section = "Square"
 $Weight_{max} = 1249 \text{ lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 526.46 \text{ lbf}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 3936.8 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1BL$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_max} \cdot L_{u_max}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 4164.89 \text{ lbf}$

$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}}$ $P_{vLwind} = 1469 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 576.51 \cdot \text{lbf}$

Design Forces (continued_

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(L_{u_max}, W_{u_max}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 2305.55 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 503.8 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 187.92 \text{ lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 641.5 \text{ lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 642 \text{ lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756 \text{ lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \text{ in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 2.97 \text{ kip}\cdot\text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \text{ kip}\cdot\text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.15 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 99.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 58.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 43.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $Weight_{min} = 942 \cdot \text{lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 3936.8 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 4164.89 \text{ lbf}$

$P_{vL,wind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vL,wind} = 1469 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vL,wind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 615.33 \cdot \text{lbf}$

Design Forces (continued_

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 2305.55 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 504 \cdot \text{lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 265.56 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 654.44 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 654.44 \cdot \text{lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 3.03 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.15 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

**Equipment: Lennox
Models: KCA-M, KGA-M, KHA-M 092-150
and LCH-M, LGH-M 092-150 (Worst Case)
for use with Curbs Plus Curb
LENNOX K-SERIES/LGH-LCH 092-150**

sub _{matrix1} =	⎧	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"	⎫
		"KCA-092-M"	99.25	58.13	43.38	25.5	1099	94.75	53.63	
		"KCA-102-M"	99.25	58.13	43.38	25.5	1119	94.75	53.63	
		"KCA-120-M"	99.25	58.13	43.38	25.5	1166	94.75	53.63	
		"KCA-150-M"	99.25	58.13	43.38	25.5	1256	94.75	53.63	
		"KGA-092-M"	99.25	58.13	43.38	25.5	1140	94.75	53.63	
		"KGA-102-M"	99.25	58.13	43.38	25.5	1161	94.75	53.63	
		"KGA-120-M"	99.25	58.13	43.38	25.5	1202	94.75	53.63	
		"KGA-150-M"	99.25	58.13	43.38	25.5	1291	94.75	53.63	
sub _{matrix2} =	⎧	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"	⎫
		"KIIA-092-M"	99.25	58.13	43.38	25.5	1210	94.75	40.88	
		"KIIA-102-M"	99.25	58.13	43.38	25.5	1241	94.75	53.63	
		"KIIA-120-M"	99.25	58.13	43.38	25.5	1314	94.75	53.63	
sub _{matrix3} =	⎧	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"	⎫
		"LCH-092-M"	99.25	58.13	43.38	25.5	1277	94.75	53.63	
		"LCH-102-M"	99.25	58.13	43.38	25.5	1284	94.75	53.63	
		"LCH-120-M"	99.25	58.13	43.38	25.5	1327	94.75	53.63	
		"LCH-150-M"	99.25	58.13	43.38	25.5	1366	94.75	53.63	
		"LGH-092-M"	99.25	58.13	43.38	25.5	1319	94.75	53.63	
		"LGH-102-M"	99.25	58.13	43.38	25.5	1327	94.75	53.63	
		"LGH-120-M"	99.25	58.13	43.38	25.5	1362	94.75	53.63	
		"LGH-150-M"	99.25	58.13	43.38	25.5	1400	94.75	53.63	

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 99.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_max} = 58.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_max} = 43.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross_Section = "Square"
 $Weight_{max} = 1400 \text{ lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 614.19 \text{ lbf}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 3936.8 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_max} \cdot L_{u_max}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 4164.89 \text{ lbf}$

$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}}$ $P_{vLwind} = 1469 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 550.19 \cdot \text{lbf}$

Design Forces (continued_

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(L_{u_max}, W_{u_max}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 2305.55 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 503.8 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 135.28 \text{ lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 632.73 \text{ lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 633 \text{ lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756 \text{ lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \text{ in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 2.93 \text{ kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \text{ kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.14 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 99.25 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 58.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 43.38 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $\text{Weight}_{min} = 1099 \cdot \text{lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{\text{Weight}_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than 0.1Bh, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 3936.8 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than 0.1BL, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 4164.89 \text{ lbf}$

$P_{vL,wind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vL,wind} = 1469 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$\text{Uplift}_L := \max\left(0 \text{ lbf}, \frac{P_{vL,wind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$\text{Uplift}_L = 589.8 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(I_{u_min}, W_{u_min}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 2305.55 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 504 \cdot \text{lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 1 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 214.51 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 645.93 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 645.93 \cdot \text{lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 2.99 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.15 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

**Equipment: Lennox
Models: KCA, KGA, KHA 180-300
and LCA, LCH, LGC, LGH 248-300 (Worst Case)
for use with Curbs Plus Curb
LENNOX L/T/K-SERIES/LGH-LCH 156-300S**

sub_matrix1 =

"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
"KCA-180"	106.5	90.13	51	40	1855	101.5	85.63
"KCA-210"	106.5	90.13	51	39.25	2001	101.5	85.63
"KCA-240"	120.19	90.13	51	37.5	2270	101.5	85.63
"KCA-300"	120.19	90.13	51	37.5	2270	101.5	85.63
"KGA-180"	106.5	90.13	51	40	1855	101.5	85.63
"KGA-210"	106.5	90.13	51	39.25	2001	101.5	85.63
"KGA-240"	120.19	90.13	51	37.5	2270	101.5	85.63
"KGA-300"	120.19	90.13	51	37.5	2270	101.5	85.63

sub_matrix2 =

"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
"KHA-180"	128.5	90.13	51	39.75	1950	101.5	85.63
"KHA-240"	128.5	90.13	51	39	2150	101.5	85.63
"LCA-248"	132.38	90.13	61.75	37.25	2910	101.5	85.63
"LCA-300"	132.38	90.13	61.75	37.25	2910	101.5	85.63
"LCH-156"	106.5	90.13	51	39.75	1850	101.5	85.63
"LCH-180"	120.19	90.13	51	39.5	2070	101.5	85.63
"LCH-210"	120.19	90.13	51	39.5	2180	101.5	85.63
"LCH-240"	120.19	90.13	51	39	2280	101.5	85.63

sub_matrix3 =

"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
"LCH-300"	120.19	90.13	51	38.25	2344	101.5	85.63
"LGC-248"	132.38	90.13	61.75	36.75	3020	101.5	85.63
"LGC-300"	132.38	90.13	61.75	36.75	3020	101.5	85.63
"LGH-180"	120.19	90.13	51	39.5	2221	101.5	85.63
"LGH-210"	120.19	90.13	51	39.5	2330	101.5	85.63
"LGH-240"	120.19	90.13	51	39	2430	101.5	85.63
"LGH-300"	120.19	90.13	51	38.25	2496	101.5	85.63

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 132.38 \cdot \text{in}$ <---outside length of unit
 $W_{u_max} = 90.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_max} = 61.75 \cdot \text{in}$ <---height of unit from top of curb
 Cross_Section = "Square"
 $Weight_{max} = 3020 \text{ lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 1231.46 \text{ lbf} \quad \text{<---minimum dead load per linear foot acting vertically on curb. } L_{cg} \text{ (distance to center of gravity assumed at mid point)}$$

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 7475.08 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1BL$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_max} \cdot L_{u_max}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 8613.14 \text{ lbf}$

$$P_{vL,wind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}} \quad P_{vL,wind} = 2561 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vL,wind} - 0.6P_{dead}}{N_{clipsL}}\right) \quad \text{<---uplift per clip}$$

$Uplift_L = 910.97 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \text{<---factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(L_{u_max}, W_{u_max}) \quad \text{<---vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \text{<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 5089.27 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 1187.01 \text{ lbf} \quad \text{<---vertical wind force on curb}$$

$$N_{clipsW} = 2 \quad \text{<---number of clips on short side (Width) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_W = 224.07 \text{ lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad \text{Uplift} = 984.28 \text{ lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 984 \text{ lbf} \quad \text{<---actual shear on clip}$$

$$V_{clip} = 2756 \text{ lbf} \quad \text{<---allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \text{ in} \quad \text{<---moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 4.55 \text{ kip} \cdot \text{in} \quad \text{<---actual bending moment in clip}$$

$$M_a = 9.73 \text{ kip} \cdot \text{in} \quad \text{<---allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.35 \quad \text{<---interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 106.5 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 90.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 51 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $Weight_{min} = 1850 \cdot \text{lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 4966.98 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 6929.56 \text{ lbf}$

$P_{vL,wind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vL,wind} = 1405 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vL,wind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 457.89 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \text{<---factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \text{<---vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \text{<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 4203.28 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 1006 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$$N_{clipsW} = 2 \quad \text{<---number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_W = 258.42 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 805 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 805 \cdot \text{lbf} \quad \text{<---actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \text{<---allowable shear on clip}$$

Bending

$$c_{force} = 4.63 \cdot \text{in} \quad \text{<---moment arm}$$

$$m_{clip} := c_{force} \cdot Uplift \quad m_{clip} = 3.72 \cdot \text{kip} \cdot \text{in} \quad \text{<---actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \text{<---allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.23 \quad \text{<---interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Equipment: Lennox
Models: KCA-M, KGA-M, KHA-M 180-300
and LCA-M, LCH-M, LGC-M, LGH-M 248-300
(Worst Case) for use with Curbs Plus Curb
LENNOX L/T/K-SERIES/LGH-LCH 156-300S

sub _{matrix1} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KCA-180-M"	106.5	90.13	51	42.5	2180	101.5	85.63
	"KCA-210-M"	106.5	90.13	51	41.75	2325	101.5	85.63
	"KCA-240-M"	120.19	90.13	51	39.5	2595	101.5	85.63
	"KGA-180-M"	106.5	90.13	51	42.5	2180	101.5	85.63
	"KGA-210-M"	106.5	90.13	51	41.75	2325	101.5	85.63
	"KGA-240-M"	120.19	90.13	51	39.5	2595	101.5	85.63
	"KIIA-180-M"	128.5	90.13	51	41.75	2270	101.5	85.63
"KIIA-240-M"	128.5	90.13	51	41	2480	101.5	85.63	
sub _{matrix2} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"LCII-156-M"	106.5	90.13	51	42.75	2159	101.5	85.63
	"LCII-180-M"	120.19	90.13	51	42	2350	101.5	85.63
	"LCII-210-M"	120.19	90.13	51	42	2470	101.5	85.63
	"LCH-240-M"	120.19	90.13	51	41.5	2571	101.5	85.63
	"LGH-180-M"	120.19	90.13	51	42	2505	101.5	85.63
	"LGH-210-M"	120.19	90.13	51	42	2615	101.5	85.63
"LGH-240-M"	120.19	90.13	51	41.5	2716	101.5	85.63	
sub _{matrix3} =	"Unit"	"Lu (in)"	"Wu (in)"	"Hu (in)"	"Lcg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
	"KCA-300-M"	120.19	90.13	51	39.5	2595	101.5	85.63
	"KGA-300-M"	120.19	90.13	51	39.5	2595	101.5	85.63

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 120.19\text{-in}$	<---outside length of unit
$W_{u_max} = 90.13\text{-in}$	<---outside width of unit
$H_{u_max} = 51\text{-in}$	<---height of unit from top of curb
Cross_Section = "Square"	
$Weight_{max} = 2716\text{ lbf}$	<---installation weight of mechanical unit.

Design Forces

Dead Forces

$$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 1250.64\text{ lbf} \quad \text{<---minimum dead load per linear foot acting vertically on curb. } L_{cg} \text{ (distance to center of gravity assumed at mid point)}$$

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$	<---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$	<---vertical projected area of the rooftop unit, ASCE 7-10
$F_h := q_h \cdot (GC_r) \cdot A_f$	<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
$F_h = 5605.34\text{ lbf}$	

Wind uplift on unit

$GC_r := 1.5$	<---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_r := W_{u_max} \cdot L_{u_max}$	<---horizontal projected area of the rooftop unit, ASCE 7-10
$F_v := q_h \cdot (GC_r) \cdot A_r$	<---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
$F_v = 7820.15\text{ lbf}$	

$$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}} \quad P_{vLwind} = 1586\text{ lbf} \quad \text{<---vertical wind force on curb}$$

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$$Uplift_L := \max\left(0\text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right) \quad \text{<---uplift per clip}$$

$Uplift_L = 417.8\text{ lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(L_{u_max}, W_{u_max}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 4203.28 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 891.8 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 2 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 70.71 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 883.72 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 884 \cdot \text{lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756 \cdot \text{lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$c_{force} = 4.63 \cdot \text{in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := c_{force} \cdot Uplift \quad m_{clip} = 4.09 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.28 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 106.5 \text{ in}$ <---outside length of unit
 $W_{u_min} = 90.13 \text{ in}$ <---outside width of unit
 $H_{u_min} = 51 \text{ in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $Weight_{min} = 2159 \text{ lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{Weight_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 4966.98 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 6929.56 \text{ lbf}$

$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vLwind} = 1405 \text{ lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$Uplift_L = 395.45 \text{ lbf}$

Design Forces (continued_

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 4203.28 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 1006 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 2 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 195.98 \text{ lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 789.39 \text{ lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 789.39 \text{ lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756.27 \text{ lbf} \quad V_{clip} = 2756.27 \text{ lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \text{ in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 3.65 \text{ kip} \cdot \text{in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \text{ kip} \cdot \text{in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.22 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

**Equipment: Lennox
Model: LCA, LCH, LGC, LGH (Worst Case)
for use with Curbs Plus Curb
LENNOX L-SERIES 248,300H,360H**

sub_matrix1 =	{	"Unit"	"Lu (in)"	"Wu (in)"	"Hlu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
		"LCA-360"	132.38	90.13	61.75	37.25	2910	101.5	85.63
		"LGC-360"	132.38	90.13	61.75	36.75	3020	101.5	85.63
		"LCA-248-M"	132.38	90.13	61.75	40.13	3280	101.5	85.63
		"LCA-300-M"	132.38	90.13	61.75	40.13	3280	101.5	85.63
		"LCA-360-M"	132.38	90.13	61.75	40.13	3480	101.5	85.63
sub_matrix2 =	{	"LCH-300-M"	120.19	90.13	51	40.75	2635	101.5	85.63
		"Unit"	"Lu (in)"	"Wu (in)"	"Hlu (in)"	"Leg(in)"	"Wm (lbf)"	"Lc(in)"	"Wc(in)"
		"LGC-248-M"	132.38	90.13	61.75	39.75	3340	101.5	85.63
		"LGC-300-M"	132.38	90.13	61.75	39.75	3340	101.5	85.63
		"LGC-360-M"	132.38	90.13	61.75	39.75	3340	101.5	85.63
"LGH-300-M"	120.19	90.13	51	40.75	2780	101.5	85.63		

Max Unit Data (see shop drawings in Appendix)

$L_{u_max} = 132.38 \cdot \text{in}$	<---outside length of unit
$W_{u_max} = 90.13 \cdot \text{in}$	<---outside width of unit
$H_{u_max} = 61.75 \cdot \text{in}$	<---height of unit from top of curb
Cross_Section = "Square"	
$Weight_{max} = 3480 \text{ lbf}$	<---installation weight of mechanical unit.

Design Forces

Dead Forces

$$P_{dead} := \frac{Weight_{max} \cdot L_{cg_max}}{W_{u_max}} = 1549.35 \text{ lbf} \quad \text{<---minimum dead load per linear foot acting vertically on curb. } L_{cg} \text{ (distance to center of gravity assumed at mid point)}$$

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$	<---factor for rooftop structures and equipment with A_f less than 0.1Bh, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_f := H_{u_max} \cdot \max(L_{u_max}, W_{u_max})$	<---vertical projected area of the rooftop unit, ASCE 7-10
$F_h := q_h \cdot (GC_r) \cdot A_f$	<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
$F_h = 7475.08 \text{ lbf}$	

Wind uplift on unit

$GC_r := 1.5$	<---factor for rooftop structures and equipment with A_r less than 0.1BL, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
$A_r := W_{u_max} \cdot L_{u_max}$	<---horizontal projected area of the rooftop unit, ASCE 7-10
$F_v := q_h \cdot (GC_r) \cdot A_r$	<---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
$F_v = 8613.14 \text{ lbf}$	

$$P_{vLwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{W_{u_max}} \quad P_{vLwind} = 2561 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$$Uplift_L := \max\left(0 \text{ lbf}, \frac{P_{vLwind} - 0.6P_{dead}}{N_{clipsL}}\right) \quad \text{<---uplift per clip}$$

$Uplift_L = 815.6 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \leftarrow \text{factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_max} \cdot \min(L_{u_max}, W_{u_max}) \quad \leftarrow \text{vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \leftarrow \text{lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 5089.27 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_max}}{2}}{L_{u_max}} = 1187.01 \text{ lbf} \quad \leftarrow \text{vertical wind force on curb}$$

$$N_{clipsW} = 2 \quad \leftarrow \text{number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \leftarrow \text{uplift per clip}$$

$$Uplift_W = 128.7 \text{ lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 960.44 \text{ lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 960 \text{ lbf} \quad \leftarrow \text{actual shear on clip}$$

$$V_{clip} = 2756 \text{ lbf} \quad \leftarrow \text{allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \text{ in} \quad \leftarrow \text{moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 4.44 \text{ kip-in} \quad \leftarrow \text{actual bending moment in clip}$$

$$M_a = 9.73 \text{ kip-in} \quad \leftarrow \text{allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.33 \quad \leftarrow \text{interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$

Minimum Unit Data (see shop drawings in Appendix)

$L_{u_min} = 120.19 \cdot \text{in}$ <---outside length of unit
 $W_{u_min} = 90.13 \cdot \text{in}$ <---outside width of unit
 $H_{u_min} = 51 \cdot \text{in}$ <---height of unit from top of curb
 Cross Section = "Square"
 $\text{Weight}_{min} = 2635 \cdot \text{lbf}$ <---installation weight of mechanical unit.

Design Forces

Dead Forces

$P_{dead} := \frac{\text{Weight}_{min} \cdot L_{cg_min}}{W_{u_min}}$ <---minimum dead load per linear foot acting vertically on curb. Lcg (distance to center of gravity assumed at mid point)

Wind Forces

Wind blowing on Long side (Length) of unit

$GC_r := 1.9$ <---factor for rooftop structures and equipment with A_f less than $0.1B_h$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_f := H_{u_min} \cdot \max(L_{u_min}, W_{u_min})$ <---vertical projected area of the rooftop unit, ASCE 7-10
 $F_h := q_h \cdot (GC_r) \cdot A_f$ <---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10
 $F_h = 5605.34 \text{ lbf}$

Wind uplift on unit

$GC_r := 1.5$ <---factor for rooftop structures and equipment with A_r less than $0.1B_L$, Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10
 $A_r := W_{u_min} \cdot L_{u_min}$ <---horizontal projected area of the rooftop unit, ASCE 7-10
 $F_v := q_h \cdot (GC_r) \cdot A_r$ <---vertical uplift force on rooftop unit, Eq. 29.5-3 ASCE 7-10
 $F_v = 7820.15 \text{ lbf}$

$P_{vL_wind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{W_{u_min}}$ $P_{vL_wind} = 1586 \cdot \text{lbf}$ <---vertical wind force on curb

$N_{clipsL} = 2$ <---number of clips on long side (Length) of unit

$\text{Uplift}_L := \max\left(0 \text{ lbf}, \frac{P_{vL_wind} - 0.6P_{dead}}{N_{clipsL}}\right)$ <---uplift per clip

$\text{Uplift}_L = 435.56 \cdot \text{lbf}$

Design Forces (continued)

Wind Forces (continued)

Wind blowing on short side (Width) of unit

$$GC_r := 1.9 \quad \text{<---factor for rooftop structures and equipment with } A_f \text{ less than } 0.1B_h, \text{ Assumed Worst Case Condition, Section 29.5.1 ASCE 7-10}$$

$$A_f := H_{u_min} \cdot \min(L_{u_min}, W_{u_min}) \quad \text{<---vertical projected area of the rooftop unit, ASCE 7-10}$$

$$F_h := q_h \cdot (GC_r) \cdot A_f \quad \text{<---lateral force on rooftop structures, Eq. 29.5-2 ASCE 7-10}$$

$$F_h = 4203.28 \text{ lbf}$$

$$P_{vWwind} := \frac{F_h \cdot \frac{H_{u_min}}{2}}{L_{u_min}} \quad P_{vWwind} = 892 \cdot \text{lbf} \quad \text{<---vertical wind force on curb}$$

$$N_{clipsW} = 2 \quad \text{<---number of clips on long side (Length) of unit}$$

$$Uplift_W := \max\left(0 \text{ lbf}, \frac{P_{vWwind} - 0.6P_{dead}}{N_{clipsW}}\right) \quad \text{<---uplift per clip}$$

$$Uplift_W = 88.48 \cdot \text{lbf}$$

$$Uplift := \max\left[Uplift_L, Uplift_W, \frac{F_v - 0.6 \cdot P_{dead}}{2 \cdot (N_{clipsW} + N_{clipsL})}\right] \quad Uplift = 888.16 \cdot \text{lbf}$$

Check Clip

Shear

$$v_{clip} := Uplift \quad v_{clip} = 888.16 \cdot \text{lbf} \quad \text{<---actual shear on clip}$$

$$V_{clip} = 2756.27 \cdot \text{lbf} \quad V_{clip} = 2756.27 \cdot \text{lbf} \quad \text{<---allowable shear on clip}$$

Bending

$$e_{force} = 4.63 \cdot \text{in} \quad \text{<---moment arm}$$

$$m_{clip} := e_{force} \cdot Uplift \quad m_{clip} = 4.11 \cdot \text{kip} \cdot \text{in} \quad \text{<---actual bending moment in clip}$$

$$M_a = 9.73 \cdot \text{kip} \cdot \text{in} \quad \text{<---allowable bending in clip}$$

Interaction

$$\text{Interaction} := \left(\frac{v_{clip}}{V_{clip}}\right)^2 + \left(\frac{m_{clip}}{M_a}\right)^2 = 0.28 \quad \text{<---interaction for bending and shear, Section C3.3 - Must be less than 1.0}$$




Appendix

Drawing Date:

REV: 10-10-14

Approved By:

14 GA GALVANIZED CONSTRUCTION



LENNOX: L77K-SERIES/LGH-LCH 024-150 UNITS USE (8) CLIPS PER CURB MAX (SEE INSTALL SHEET)

LENNOX: L77K-SERIES/LGH-LCH 156-360 UNITS USE (10) CLIPS PER CURB MAX (SEE INSTALL SHEET)

ATTACH VIA (8) 1/4" X 14 X 1 1/4" TEK SCREWS

QTY.: SET(S) (10 CLIPS PER SET)

PROJECT NAME:

CITY, STATE:

CUSTOMER:

JOB NUMBER:

TAG:

CURBS PLUS, INC.


8767 Alabama Hwy
Ringgold, GA 30736
Phone: (706) 858-1188 / FAX (706) 866-2339
website: www.curbs-plus.com

LENNOX UNIT CLIPS
MODEL# L7T/K/S-SERIES/LGH-LCH 024-360
LENNOX PART# X6523



March Adams & Associates
Consulting Engineers
P.O. Box 3689
310 Dodds Avenue
Chattanooga, TN 37404
(423) 698-6675

Job Name: Curbs Plus No. 18-098
Prepared By: THOMAS A. RETSECK Date: March 2018
Sheet No: _____ of _____ Scale: N.T.S.
Topic: Clip Locations for Curbs Plus Curb#:
Other: LENNOX T/K-SERIES/LGH-LCH 024-072
Other: _____




LENNOX T/K-SERIES/LGH-LCH 024-072
2 TO 6 TON UNITS - STANDARD AND MAX



March Adams & Associates
Consulting Engineers
P.O. Box 3689
310 Dodds Avenue
Chattanooga, TN 37404
(423) 698-6675

Job Name: Curbs Plus No. 18-098
Prepared By: THOMAS A. RETSECK Date: March 2018
Sheet No: _____ of _____ Scale: N.T.S.
Topic: Clip Locations for Curbs Plus Curb#:
Other: LENNOX K-SERIES 090 F.P.
Other: _____




LENNOX K-SERIES 090 F.P.
15 TON UNITS - STANDARD AND MAX



March Adams & Associates
Consulting Engineers
P.O. Box 3689
310 Dodds Avenue
Chattanooga, TN 37404
(423) 698-6675

Job Name: Curbs Plus No. 18-098
Prepared By: THOMAS A. RETSECK Date: March 2018
Sheet No: _____ of _____ Scale: N.T.S.
Topic: Clip Locations for Curbs Plus Curb#:
Other: LENNOX K-SERIES/LGH-LCH 092-150
Other: _____




LENNOX K-SERIES/LGH-LCH 092-150
7.5 TO 12.5 TON UNITS - STANDARD AND MAX



March Adams & Associates
Consulting Engineers
P.O. Box 3689
310 Dodds Avenue
Chattanooga, TN 37404
(423) 698-6675

Job Name: Curbs Plus No. 18-098
Prepared By: THOMAS A. RETSECK Date: March 2018
Sheet No: _____ of _____ Scale: N.T.S.
Topic: Clip Locations for Curbs Plus Curb#:
Other: LENNOX L/T/K-SERIES/LGH-LCH 156-300S
Other: _____




LENNOX K-SERIES/LGH-LCH 092-150
13 - 25 TON UNITS - STANDARD (LIMITED MAX)



March Adams & Associates
Consulting Engineers
P.O. Box 3689
310 Dodds Avenue
Chattanooga, TN 37404
(423) 698-6675

Job Name: Curbs Plus No. 18-098
Prepared By: THOMAS A. RETSECK Date: March 2018
Sheet No: _____ of _____ Scale: N.T.S.
Topic: Clip Locations for Curbs Plus Curb#:
Other: LENNOX L-SERIES 248, 300H, 360H
Other: _____



LENNOX L-SERIES 248, 300H, 360H
21, 25 AND 30 TON UNITS - STANDARD AND MAX