



CLARIFICATION LETTER #2

DATE: 5/07/2021

ISSUED BY: Miguel A. Hernandez, CFP Coordinator

IFB# 21-815-001 H.H.A. WAREHOUSE MODIFICATIONS

Please acknowledge the following clarifications by signing this form and send by email or fax: vrodriguez@hialeahhousing.org or by fax 305-887-0997:

1. Please clarify (A7, A7.1, and A7.2) subflooring & flooring scope of work. New warehouse floor shown to be broom finished concrete as shown on structural plan?
 - **The new warehouse floor will be broom finished concrete as shown on the structural plan. Sheet A7.1 & A7.2 refers to the new floor infill stair modifications at second floor of the existing warehouse.**
2. Please confirm building permit is not included in the bid?
 - **The master permit will be paid by Hialeah Housing Authority, all other permits and sub-permits shall be included in the bid contract.**
3. Is FAA permit required?
 - **No FAA Permit Required.**
4. Can we use our own spread sheet supporting the summary cost of element, or do we need to use your schedule of value form?
 - **Please use HHA schedule of Values.**

EXCEPT AS PROVIDED HEREIN, ALL TERMS AND CONDITIONS OF THE SOLICITATION REMAIN UNCHANGED AND IN FULL FORCE AND EFFECT.

ACKNOWLEDGEMENT OF RECEIPT
DATE:

COMPANY NAME:

NAME:

TITLE: