

Addendum No. 3
Noltemeyer Wynde Complex Apartments Siding Replacement

TO: All Plan Holders

FROM: Sherman Carter Barnhart Architects
2405 Harrodsburg Road
Lexington, Kentucky 40504

DATE: May 21, 2021

The purpose of this Addendum is to clarify further the requirements of the plans and specifications.

The bidders are governed by the information in this Addendum as if included in the plans and specifications.

This Addendum does hereby become a part of the Contract Documents.

Each bidder shall acknowledge receipt of this Addendum in the space provided in the Bid Form.

This Addendum consists of (1) one, 8-1/2"x11" pages.

This Addendum is being made available to all plan holders through online Housing Agency Market Place.

A. General (All Bidders are advised of the following)

1. **CLARIFICATION** – Refer to Sheets A-1 through A-3 and P-1A through P-1F. Revise Elevation and Photo Demolition and New Work Key Note "4d" to read:

"REMOVE EXISTING SIDING AND BUILDING WRAP. PROVIDE NEW BUILDING WRAP. TAPE / CAULK FULL PERIMETER OF ALL EXISTING OPENINGS. PROVIDE BUILDING WRAP FLASHING AT PERIMETER OF EXISTING OPENINGS PER MANUFACTURER'S PRINTED INSTRUCTIONS. REPAIR ANY TEARS / PUNCTURES PRIOR TO OR DURING SIDING INSTALLATION. PROVIDE NEW PREFINISHED FIBER CEMENT SIDING INSTALLED PER MANUFACTURER'S PRINTED INSTRUCTIONS".

End of Addendum