

## **Addendum No. 4**

### **Dosker Manor Fire Alarm Replacement**

TO: All Plan Holders

FROM: Sherman Carter Barnhart Architects  
2405 Harrodsburg Road  
Lexington, Kentucky 40504

DATE: June 17, 2022

The purpose of this Addendum is to clarify further the requirements of the plans and specifications.

The bidders are governed by the information in this Addendum as if included in the plans and specifications.

This Addendum does hereby become a part of the Contract Documents.

Each bidder shall acknowledge receipt of this Addendum in the space provided in the Bid Form.

This Addendum consists of one (1) page.

**This Addendum is being made available to all plan holders through online Housing Agency Market Place.**

A. Architectural Drawings

1. To clarify on the nurse call scope of work, the scope is to remove the existing pull cords and dome lights that are part of the existing nurse call system and to install blank cover plates at all locations. The new nurse call system, however, is no longer in the scope of the project. Therefore, nurse call demolition sheets are still included in the drawing set.
2. The goal of the project is to stand up the new fire alarm system(s) prior to removing the existing system(s) to eliminate the need for any/all buildings to be on a "Fire Watch".
3. Key Monitors (LMHA employees) will be necessary to escort Contractors in and out of resident rooms and will be coordinated with LMHA.
4. The existing fire alarm system provider at Dosker Manor is Johnson Controls. They will not be involved in the project until the existing system is ready to be decommissioned.

End of Addendum